



7940 Memorial Drive Plain City, Ohio 43064 (614) 873-4654

Date: May 23, 2022

Whitehouse, Village Of (606)

Attn: Steve Pilcher

Po Box 2476

Whitehouse, OH 43571

RE: Certificate of Analysis for Project - Private Drinking Water

The following report contains analytical results for samples submitted on the chain of custody dated May 10, 2022.

I have reviewed the validity of the analytical data generated. All data is reported in accordance to our laboratory QA/QC plan. Any exceptions are noted in the Case Narrative or with qualifiers in the report.

If you have any questions or need additional documentation, please contact our Office.

Sincerely,

A handwritten signature in black ink that reads "Cheryl Rex". The signature is written in a cursive style and is positioned above a solid black horizontal line.

Cheryl Rex
MASI Laboratories
QA/QC Officer
cheryl@masilabs.com
(614) 873-4654



CERTIFICATE of ANALYSIS

Microbiological/Inorganic Certification - 877

Organic Certification - 4100

Whitehouse, Village Of
 Steve Pilcher
 Po Box 2476
 Whitehouse, OH 43571

Client #: 606
 PO Number:
 Date Received: 5/10/22 12:43
 Ohio EPA Analyzed Date: 5/23/22 13:06

Sampler Name: Mike Hill
 Sample Date/Time: 5/9/22 09:27
 Sample Monitoring Point: DS000
 Sample Type: SP
 Sample Tap/Address: Hydrant 252 6035 N Texas St Whitehouse OH 43571

PWSID: OH4802612 Facility ID: DS1
 Repeat Sample #:
 Total Chlorine (mg/L):
 Free Chlorine (mg/L):
 Combined Chlorine (mg/L):

Sample ID: 969550

Lab Sample # : 2E01205-01 (Potable)

Analyte	Result	Units	Qual	Reporting Limit	MDL	Date/Time Prepared	Date/Time Analyzed	Analyst	Method
---------	--------	-------	------	-----------------	-----	--------------------	--------------------	---------	--------

Disinfection Byproducts (DBP)

Monochloroacetic Acid	ND	ug/L		2.0	0.8	05/16/22 10:09	05/16/22 22:41	JRK	EPA Method 552.3
Dichloroacetic Acid	7.7	ug/L		1.0	0.4	05/16/22 10:09	05/16/22 22:41	JRK	EPA Method 552.3
Trichloroacetic Acid	ND	ug/L		1.0	0.3	05/16/22 10:09	05/16/22 22:41	JRK	EPA Method 552.3
Monobromoacetic Acid	ND	ug/L		1.0	0.5	05/16/22 10:09	05/16/22 22:41	JRK	EPA Method 552.3
Dibromoacetic Acid	2.7	ug/L		1.0	0.5	05/16/22 10:09	05/16/22 22:41	JRK	EPA Method 552.3
HAA 5 Total	10.5	ug/L		6.0	2.4	05/16/22 10:09	05/16/22 22:41	JRK	EPA Method 552.3
<hr style="border-top: 1px dashed #000;"/>									
<i>Surrogate: 2-Bromopropanoic Acid</i>				<i>104%</i>		<i>70-130</i>			<i>EPA Method 552.3</i>
Chloroform	25.4	ug/L		0.5	0.02	05/17/22 17:00	05/17/22 17:00	DTS	EPA Method 524.2
Bromoform	1.1	ug/L		0.5	0.1	05/17/22 17:00	05/17/22 17:00	DTS	EPA Method 524.2
Bromodichloromethane	14.6	ug/L		0.5	0.04	05/17/22 17:00	05/17/22 17:00	DTS	EPA Method 524.2
Dibromochloromethane	8.5	ug/L		0.5	0.07	05/17/22 17:00	05/17/22 17:00	DTS	EPA Method 524.2
Total THM	49.6	ug/L		2.0	0.2	05/17/22 17:00	05/17/22 17:00	DTS	EPA Method 524.2
<hr style="border-top: 1px dashed #000;"/>									
<i>Surrogate: 4-Bromofluorobenzene</i>				<i>105%</i>		<i>70-130</i>			<i>EPA Method 524.2</i>
<i>Surrogate: 1,2-Dichlorobenzene-d4</i>				<i>84%</i>		<i>70-130</i>			<i>EPA Method 524.2</i>



CERTIFICATE of ANALYSIS

Microbiological/Inorganic Certification - 877
Organic Certification - 4100

Whitehouse, Village Of
Steve Pilcher
Po Box 2476
Whitehouse, OH 43571

Client #: 606
PO Number:
Date Received: 5/10/22 12:43
Ohio EPA Analyzed Date: 5/23/22 13:06

Sampler Name: Mike Hill
Sample Date/Time: 5/9/22 08:45
Sample Monitoring Point: DS202
Sample Type: SP
Sample Tap/Address: Hydrant 7344 Providence St Whitehouse OH 43571

PWSID: OH4801612 Facility ID: DS1
Repeat Sample #:
Total Chlorine (mg/L):
Free Chlorine (mg/L):
Combined Chlorine (mg/L):

Sample ID: 969549

Lab Sample # : 2E01205-02 (Potable)

Analyte	Result	Units	Qual	Reporting Limit	MDL	Date/Time Prepared	Date/Time Analyzed	Analyst	Method
---------	--------	-------	------	-----------------	-----	--------------------	--------------------	---------	--------

Disinfection Byproducts (DBP)

Monochloroacetic Acid	ND	ug/L		2.0	0.8	05/16/22 10:09	05/16/22 23:04	JRK	EPA Method 552.3
Dichloroacetic Acid	9.6	ug/L		1.0	0.4	05/16/22 10:09	05/16/22 23:04	JRK	EPA Method 552.3
Trichloroacetic Acid	0.9	ug/L	J	1.0	0.3	05/16/22 10:09	05/16/22 23:04	JRK	EPA Method 552.3
Monobromoacetic Acid	ND	ug/L		1.0	0.5	05/16/22 10:09	05/16/22 23:04	JRK	EPA Method 552.3
Dibromoacetic Acid	2.9	ug/L		1.0	0.5	05/16/22 10:09	05/16/22 23:04	JRK	EPA Method 552.3
HAA 5 Total	12.4	ug/L		6.0	2.4	05/16/22 10:09	05/16/22 23:04	JRK	EPA Method 552.3
<hr style="border-top: 1px dashed #000;"/>									
<i>Surrogate: 2-Bromopropanoic Acid</i>				<i>108%</i>		<i>70-130</i>			<i>EPA Method 552.3</i>
Chloroform	16.7	ug/L		0.5	0.02	05/17/22 17:24	05/17/22 17:24	DTS	EPA Method 524.2
Bromoform	0.8	ug/L		0.5	0.1	05/17/22 17:24	05/17/22 17:24	DTS	EPA Method 524.2
Bromodichloromethane	8.4	ug/L		0.5	0.04	05/17/22 17:24	05/17/22 17:24	DTS	EPA Method 524.2
Dibromochloromethane	5.1	ug/L		0.5	0.07	05/17/22 17:24	05/17/22 17:24	DTS	EPA Method 524.2
Total THM	31.1	ug/L		2.0	0.2	05/17/22 17:24	05/17/22 17:24	DTS	EPA Method 524.2
<hr style="border-top: 1px dashed #000;"/>									
<i>Surrogate: 4-Bromofluorobenzene</i>				<i>106%</i>		<i>70-130</i>			<i>EPA Method 524.2</i>
<i>Surrogate: 1,2-Dichlorobenzene-d4</i>				<i>80%</i>		<i>70-130</i>			<i>EPA Method 524.2</i>



CERTIFICATE of ANALYSIS

Microbiological/Inorganic Certification - 877

Organic Certification - 4100

Whitehouse, Village Of
 Steve Pilcher
 Po Box 2476
 Whitehouse, OH 43571

Client #: 606
 PO Number:
 Date Received: 5/10/22 12:43
 Ohio EPA Analyzed Date: 5/23/22 13:06

Sampler Name: Mike Hill
 Sample Date/Time: 5/9/22 09:05
 Sample Monitoring Point: DS201
 Sample Type: SP
 Sample Tap/Address: Hydrant 7125 Berkey Southern Rd Whitehouse 43571

PWSID: OH4801612 Facility ID: DS1
 Repeat Sample #:
 Total Chlorine (mg/L):
 Free Chlorine (mg/L):
 Combined Chlorine (mg/L):

Sample ID: 969548

Lab Sample # : 2E01205-03 (Potable)

Analyte	Result	Units	Qual	Reporting Limit	MDL	Date/Time Prepared	Date/Time Analyzed	Analyst	Method
---------	--------	-------	------	-----------------	-----	--------------------	--------------------	---------	--------

Disinfection Byproducts (DBP)

Monochloroacetic Acid	ND	ug/L		2.0	0.8	05/16/22 10:09	05/16/22 23:28	JRK	EPA Method 552.3
Dichloroacetic Acid	7.9	ug/L		1.0	0.4	05/16/22 10:09	05/16/22 23:28	JRK	EPA Method 552.3
Trichloroacetic Acid	ND	ug/L		1.0	0.3	05/16/22 10:09	05/16/22 23:28	JRK	EPA Method 552.3
Monobromoacetic Acid	ND	ug/L		1.0	0.5	05/16/22 10:09	05/16/22 23:28	JRK	EPA Method 552.3
Dibromoacetic Acid	2.8	ug/L		1.0	0.5	05/16/22 10:09	05/16/22 23:28	JRK	EPA Method 552.3
HAA 5 Total	10.7	ug/L		6.0	2.4	05/16/22 10:09	05/16/22 23:28	JRK	EPA Method 552.3
<hr style="border-top: 1px dashed black;"/>									
<i>Surrogate: 2-Bromopropanoic Acid</i>				<i>106%</i>		<i>70-130</i>			<i>EPA Method 552.3</i>
Chloroform	26.5	ug/L		0.5	0.02	05/18/22 15:30	05/18/22 15:30	KJT	EPA Method 524.2
Bromoform	1.1	ug/L		0.5	0.1	05/18/22 15:30	05/18/22 15:30	KJT	EPA Method 524.2
Bromodichloromethane	14.3	ug/L		0.5	0.04	05/18/22 15:30	05/18/22 15:30	KJT	EPA Method 524.2
Dibromochloromethane	8.7	ug/L		0.5	0.07	05/18/22 15:30	05/18/22 15:30	KJT	EPA Method 524.2
Total THM	50.4	ug/L		2.0	0.2	05/18/22 15:30	05/18/22 15:30	KJT	EPA Method 524.2
<hr style="border-top: 1px dashed black;"/>									
<i>Surrogate: 4-Bromofluorobenzene</i>				<i>106%</i>		<i>70-130</i>			<i>EPA Method 524.2</i>
<i>Surrogate: 1,2-Dichlorobenzene-d4</i>				<i>90%</i>		<i>70-130</i>			<i>EPA Method 524.2</i>



CERTIFICATE of ANALYSIS

Microbiological/Inorganic Certification - 877

Organic Certification - 4100

Whitehouse, Village Of
 Steve Pilcher
 Po Box 2476
 Whitehouse, OH 43571

Client #: 606
 PO Number:
 Date Received: 5/10/22 12:43
 Ohio EPA Analyzed Date: 5/23/22 13:06

Sampler Name: Mike Hill
 Sample Date/Time: 5/9/22 13:15
 Sample Monitoring Point: DS000
 Sample Type: SP
 Sample Tap/Address: Hydrant 426, 8911 Dutch Rd Whitehouse OH 43571

PWSID: OH4801612 Facility ID: DS1
 Repeat Sample #:
 Total Chlorine (mg/L):
 Free Chlorine (mg/L):
 Combined Chlorine (mg/L):

Sample ID: 969551

Lab Sample # : 2E01205-04 (Potable)

Analyte	Result	Units	Qual	Reporting Limit	MDL	Date/Time Prepared	Date/Time Analyzed	Analyst	Method
---------	--------	-------	------	-----------------	-----	--------------------	--------------------	---------	--------

Disinfection Byproducts (DBP)

Monochloroacetic Acid	ND	ug/L		2.0	0.8	05/16/22 10:09	05/16/22 23:51	JRK	EPA Method 552.3
Dichloroacetic Acid	7.3	ug/L		1.0	0.4	05/16/22 10:09	05/16/22 23:51	JRK	EPA Method 552.3
Trichloroacetic Acid	ND	ug/L		1.0	0.3	05/16/22 10:09	05/16/22 23:51	JRK	EPA Method 552.3
Monobromoacetic Acid	ND	ug/L		1.0	0.5	05/16/22 10:09	05/16/22 23:51	JRK	EPA Method 552.3
Dibromoacetic Acid	2.5	ug/L		1.0	0.5	05/16/22 10:09	05/16/22 23:51	JRK	EPA Method 552.3
HAA 5 Total	9.9	ug/L		6.0	2.4	05/16/22 10:09	05/16/22 23:51	JRK	EPA Method 552.3
<hr style="border-top: 1px dashed black;"/>									
<i>Surrogate: 2-Bromopropanoic Acid</i>				<i>102%</i>		<i>70-130</i>			<i>EPA Method 552.3</i>
Chloroform	25.5	ug/L		0.5	0.02	05/17/22 18:11	05/17/22 18:11	DTS	EPA Method 524.2
Bromoform	1.0	ug/L		0.5	0.1	05/17/22 18:11	05/17/22 18:11	DTS	EPA Method 524.2
Bromodichloromethane	14.8	ug/L		0.5	0.04	05/17/22 18:11	05/17/22 18:11	DTS	EPA Method 524.2
Dibromochloromethane	8.3	ug/L		0.5	0.07	05/17/22 18:11	05/17/22 18:11	DTS	EPA Method 524.2
Total THM	49.6	ug/L		2.0	0.2	05/17/22 18:11	05/17/22 18:11	DTS	EPA Method 524.2
<hr style="border-top: 1px dashed black;"/>									
<i>Surrogate: 4-Bromofluorobenzene</i>				<i>103%</i>		<i>70-130</i>			<i>EPA Method 524.2</i>
<i>Surrogate: 1,2-Dichlorobenzene-d4</i>				<i>78%</i>		<i>70-130</i>			<i>EPA Method 524.2</i>



CERTIFICATE of ANALYSIS

Microbiological/Inorganic Certification - 877

Organic Certification - 4100

Whitehouse, Village Of
 Steve Pilcher
 Po Box 2476
 Whitehouse, OH 43571

Client #: 606
 PO Number:
 Date Received: 5/10/22 12:43
 Ohio EPA Analyzed Date: 5/23/22 13:06

Sampler Name: Mike Hill
 Sample Date/Time: 5/9/22 12:50
 Sample Monitoring Point: DS000
 Sample Type: SP
 Sample Tap/Address: Hydrant 405 9565 Bucher Rd Whitehouse OH 43571

PWSID: OH4801612 Facility ID: DS1
 Repeat Sample #:
 Total Chlorine (mg/L):
 Free Chlorine (mg/L):
 Combined Chlorine (mg/L):

Sample ID: 969552

Lab Sample # : 2E01205-05 (Potable)

Analyte	Result	Units	Qual	Reporting Limit	MDL	Date/Time Prepared	Date/Time Analyzed	Analyst	Method	
Disinfection Byproducts (DBP)										
Monochloroacetic Acid	ND	ug/L		2.0	0.8	05/16/22 10:09	05/17/22 00:15	JRK	EPA Method 552.3	
Dichloroacetic Acid	8.6	ug/L		1.0	0.4	05/16/22 10:09	05/17/22 00:15	JRK	EPA Method 552.3	
Trichloroacetic Acid	0.6	ug/L	J	1.0	0.3	05/16/22 10:09	05/17/22 00:15	JRK	EPA Method 552.3	
Monobromoacetic Acid	ND	ug/L		1.0	0.5	05/16/22 10:09	05/17/22 00:15	JRK	EPA Method 552.3	
Dibromoacetic Acid	2.4	ug/L		1.0	0.5	05/16/22 10:09	05/17/22 00:15	JRK	EPA Method 552.3	
HAA 5 Total	11.0	ug/L		6.0	2.4	05/16/22 10:09	05/17/22 00:15	JRK	EPA Method 552.3	
<hr style="border-top: 1px dashed #000;"/>										
<i>Surrogate: 2-Bromopropanoic Acid</i>			<i>105%</i>				<i>70-130</i>	<i>EPA Method 552.3</i>		
Chloroform	14.9	ug/L		0.5	0.02	05/18/22 15:54	05/18/22 15:54	KJT	EPA Method 524.2	
Bromoform	0.7	ug/L		0.5	0.1	05/18/22 15:54	05/18/22 15:54	KJT	EPA Method 524.2	
Bromodichloromethane	7.3	ug/L		0.5	0.04	05/18/22 15:54	05/18/22 15:54	KJT	EPA Method 524.2	
Dibromochloromethane	4.7	ug/L		0.5	0.07	05/18/22 15:54	05/18/22 15:54	KJT	EPA Method 524.2	
Total THM	27.6	ug/L		2.0	0.2	05/18/22 15:54	05/18/22 15:54	KJT	EPA Method 524.2	
<hr style="border-top: 1px dashed #000;"/>										
<i>Surrogate: 4-Bromofluorobenzene</i>			<i>108%</i>				<i>70-130</i>	<i>EPA Method 524.2</i>		
<i>Surrogate: 1,2-Dichlorobenzene-d4</i>			<i>90%</i>				<i>70-130</i>	<i>EPA Method 524.2</i>		

The contents of this report apply to the sample(s) analyzed in accordance with the chain of custody document. No duplication of this report is allowed, except in its entirety.



CERTIFICATE of ANALYSIS

Microbiological/Inorganic Certification - 877

Organic Certification - 4100

Whitehouse, Village Of
 Steve Pilcher
 Po Box 2476
 Whitehouse, OH 43571

Client #: 606
 PO Number:
 Date Received: 5/10/22 12:43
 Ohio EPA Analyzed Date: 5/23/22 13:06

Sampler Name: Mike Hill
 Sample Date/Time: 5/9/22 08:25
 Sample Monitoring Point: DS000
 Sample Type: SP
 Sample Tap/Address: Hose Bib 6763 Gilead St Whitehouse OH 43571

PWSID: OH4801612 Facility ID: DS1
 Repeat Sample #:
 Total Chlorine (mg/L):
 Free Chlorine (mg/L):
 Combined Chlorine (mg/L):

Sample ID: 969554

Lab Sample # : 2E01205-06 (Potable)

Analyte	Result	Units	Qual	Reporting Limit	MDL	Date/Time Prepared	Date/Time Analyzed	Analyst	Method
---------	--------	-------	------	-----------------	-----	--------------------	--------------------	---------	--------

Disinfection Byproducts (DBP)

Chloroform	6.3	ug/L		0.5	0.02	05/18/22 16:17	05/18/22 16:17	KJT	EPA Method 524.2
Bromoform	0.7	ug/L		0.5	0.1	05/18/22 16:17	05/18/22 16:17	KJT	EPA Method 524.2
Bromodichloromethane	4.8	ug/L		0.5	0.04	05/18/22 16:17	05/18/22 16:17	KJT	EPA Method 524.2
Dibromochloromethane	3.9	ug/L		0.5	0.07	05/18/22 16:17	05/18/22 16:17	KJT	EPA Method 524.2
Total THM	15.6	ug/L		2.0	0.2	05/18/22 16:17	05/18/22 16:17	KJT	EPA Method 524.2

<i>Surrogate: 4-Bromofluorobenzene</i>	<i>108%</i>	<i>70-130</i>	<i>EPA Method 524.2</i>
<i>Surrogate: 1,2-Dichlorobenzene-d4</i>	<i>86%</i>	<i>70-130</i>	<i>EPA Method 524.2</i>



CERTIFICATE of ANALYSIS

Microbiological/Inorganic Certification - 877

Organic Certification - 4100

Whitehouse, Village Of
 Steve Pilcher
 Po Box 2476
 Whitehouse, OH 43571

Client #: 606
 PO Number:
 Date Received: 5/10/22 12:43
 Ohio EPA Analyzed Date: 5/23/22 13:06

Sampler Name: Mike Hill
 Sample Date/Time: 5/9/22 10:35
 Sample Monitoring Point: DS000
 Sample Type: SP
 Sample Tap/Address: Hydrant 6317 Finel Rd Whitehouse OH 43571

PWSID: OH4801612 Facility ID: DS1
 Repeat Sample #:
 Total Chlorine (mg/L):
 Free Chlorine (mg/L):
 Combined Chlorine (mg/L):

Sample ID: 969553

Lab Sample # : 2E01205-07 (Potable)

Analyte	Result	Units	Qual	Reporting Limit	MDL	Date/Time Prepared	Date/Time Analyzed	Analyst	Method
---------	--------	-------	------	-----------------	-----	--------------------	--------------------	---------	--------

Disinfection Byproducts (DBP)

Chloroform	4.2	ug/L		0.5	0.02	05/18/22 16:40	05/18/22 16:40	KJT	EPA Method 524.2
Bromoform	0.5	ug/L	J	0.5	0.1	05/18/22 16:40	05/18/22 16:40	KJT	EPA Method 524.2
Bromodichloromethane	3.3	ug/L		0.5	0.04	05/18/22 16:40	05/18/22 16:40	KJT	EPA Method 524.2
Dibromochloromethane	2.8	ug/L		0.5	0.07	05/18/22 16:40	05/18/22 16:40	KJT	EPA Method 524.2
Total THM	10.8	ug/L		2.0	0.2	05/18/22 16:40	05/18/22 16:40	KJT	EPA Method 524.2

<i>Surrogate: 4-Bromofluorobenzene</i>	<i>110%</i>	<i>70-130</i>	<i>EPA Method 524.2</i>
<i>Surrogate: 1,2-Dichlorobenzene-d4</i>	<i>93%</i>	<i>70-130</i>	<i>EPA Method 524.2</i>



CERTIFICATE of ANALYSIS

Microbiological/Inorganic Certification - 877

Organic Certification - 4100

Whitehouse, Village Of
Steve Pilcher
Po Box 2476
Whitehouse, OH 43571

Client #: 606
PO Number:
Date Received: 5/10/22 12:43
Ohio EPA Analyzed Date: 5/23/22 13:06

Notes and Definitions

Item	Definition
J	Analyte was positively identified, the associated numerical value is estimated.
ND	Analyte NOT DETECTED at or above the minimum detection limit (MDL)
mg/kg Dry	Sample results reported on a dry weight basis.
ug/L	ppb/Part per Billion.
mg/L	ppm/Part per Million.
!	Analyte is at or above the Maximum Contaminate Level.
RPD	Relative Percent Difference
%REC	Percent Recovery
Source	Sample that was matrix spiked or duplicated.

Notes:

1. Calculated analytes are based on raw data and may not reflect the rounding of the individual compounds.
2. Samples are analyzed using the information received on the request sheet and may not be analyzed when the parameters fall outside required guidelines.



ENVIRONMENTAL LABORATORIES

7940 Memorial Drive
Plain City, OH 43064
614-873-4654

2E01205-02

AR # 969549
Received: 5/10/2022
Matrix: Potable

ater
Request Sheet

st Appear on Bottle: 969549

SDS information *:

Client #: 606 Client Name: Village of Whitehouse County: Lucas P.O.# _____

Sampler Name: Mike Hill SMP ID: D5202 Sample Type: Compliance (C)
 New Well (N)
 Special/Other (O)

Sample Tap: Hydrant Date Collected: 05/09/22 Time Collected: 08:45 am
(MM/DD/YY) (hh:mm am/pm)

Tap Address: 7344 Providence St, Whitehouse, Oh. 43571

Public Sample PWS ID #: 4801612 Facility ID #: D51 Private Sample

Non-Preserved Parameters	Misc. Parameters & Preservatives	SOC Parameter Groups
<input type="checkbox"/> 183 Asbestos	<input type="checkbox"/> 154 VOC (Ascorbic Acid/HCL) 524.2	<input type="checkbox"/> 900 GROUP 1 Method 525.2
<input type="checkbox"/> 158 Total (Gross) Alpha	<input checked="" type="checkbox"/> 213 TTHM (Ascorbic Acid/HCL) 524.2	<input type="checkbox"/> 899 GROUP 2 Method 515.3
<input type="checkbox"/> 159 Total (Gross) Beta	<input checked="" type="checkbox"/> 375 HAA5 (NH4CL) 552.3	<input type="checkbox"/> 903 GROUP 2 Method 531.1
<input type="checkbox"/> 254 Radium 228	<input type="checkbox"/> 171 Toluene 524.2 or 8260	<input type="checkbox"/> 898 GROUP 3 Method 508
	<input type="checkbox"/> 174 BTEX (Ascorbic Acid/HCL)	<input type="checkbox"/> 904 GROUP 3 Method 547
	<input type="checkbox"/> 317 Lithium	<input type="checkbox"/> 905 GROUP 3 Method 549.2
<input type="checkbox"/> 371 UV254	<input type="checkbox"/> 134 Titanium	<input type="checkbox"/> 900 GROUP 4 Method 525.2
<input type="checkbox"/> 354 DOC	<input type="checkbox"/> 157 Total Organic Halogens	<input type="checkbox"/> 901 GROUP 4 Method 548.1
<input type="checkbox"/> 1080 SUVA	<input type="checkbox"/> 366 Hydrogen Sulfide	<input type="checkbox"/> 701 Alachlor 525.2
	<input type="checkbox"/> 123 Sulfide	<input type="checkbox"/> 702 Atrazine 525.2
<input type="checkbox"/> 166 Bromide		<input type="checkbox"/> 707 Simazine 525.2
<input type="checkbox"/> 34 Chloride	<input type="checkbox"/> 1243 HAB Total Microcystins	<input type="checkbox"/> SOC
<input type="checkbox"/> 1195 Bromide Chloride Ratio		<input type="checkbox"/> SOC
<input type="checkbox"/> 746 2,3,7,8-TCDD (Dioxin)	<input type="checkbox"/> 1258 HAB Cyanobacteria Screening	<input type="checkbox"/> SOC
<input type="checkbox"/> 271 PAH 525.2 or 8270		<input type="checkbox"/> SOC
<input type="checkbox"/> 124 Sulfite		<input type="checkbox"/> SOC
<input type="checkbox"/> Other	Office Use Only: <u>7</u>	
<input type="checkbox"/> Other		
<input type="checkbox"/> Other		
<input type="checkbox"/> Other		
<input type="checkbox"/> Other		
<input type="checkbox"/> Other		
		<input type="checkbox"/> 9050 MASI Use Only

N: _____ Total Containers: 1

S: _____

U: _____

Route: JLS 220

Office/Lab: HL

COOLER: _____

REVISED 05-19-21 DN

C

MASI [®]

ENVIRONMENTAL
LABORATORIES

7940 Memorial Drive
Plain City, OH 43064
614-873-4654

2E01205-04

AR # 969551
Received: 5/10/2022
Matrix: Potable

Vater Request Sheet

Must Appear on Bottle: **969551**
SDS information **

Client #: 606 Client Name: Village of Whitehouse County: Lucas P.O.# _____

Sampler Name: Mike Hill SMP ID: D5000 Sample Type: Compliance (C)
 New Well (N)
 Special/Other (O)

Sample Tap: Hydrant # 426 Date Collected: 05/09/22 Time Collected: 19:15 pm
(MM/DD/YY) (hh:mm am/pm)

Tap Address: 8911 Dutch Rd., Whitehouse, Oh. 43571

Public Sample PWS ID #: 4801612 Facility ID #: DS1 Private Sample

Non-Preserved Parameters	Misc. Parameters & Preservatives	SOC Parameter Groups
<input type="checkbox"/> 183 Asbestos	<input type="checkbox"/> 154 VOC (Ascorbic Acid/HCL) 524.2	<input type="checkbox"/> 900 GROUP 1 Method 525.2
<input type="checkbox"/> 158 Total (Gross) Alpha	<input checked="" type="checkbox"/> 213 TTHM (Ascorbic Acid/HCL) 524.2	<input type="checkbox"/> 899 GROUP 2 Method 515.3
<input type="checkbox"/> 159 Total (Gross) Beta	<input checked="" type="checkbox"/> 375 HAA5 (NH4CL) 552.3	<input type="checkbox"/> 903 GROUP 2 Method 531.1
<input type="checkbox"/> 254 Radium 228	<input type="checkbox"/> 171 Toluene 524.2 or 8260	<input type="checkbox"/> 898 GROUP 3 Method 508
	<input type="checkbox"/> 174 BTEX (Ascorbic Acid/HCL)	<input type="checkbox"/> 904 GROUP 3 Method 547
	<input type="checkbox"/> 317 Lithium	<input type="checkbox"/> 905 GROUP 3 Method 549.2
<input type="checkbox"/> 371 UV254	<input type="checkbox"/> 134 Titanium	<input type="checkbox"/> 900 GROUP 4 Method 525.2
<input type="checkbox"/> 354 DOC	<input type="checkbox"/> 157 Total Organic Halogens	<input type="checkbox"/> 901 GROUP 4 Method 548.1
<input type="checkbox"/> 1080 SUVA	<input type="checkbox"/> 366 Hydrogen Sulfide	<input type="checkbox"/> 701 Alachlor 525.2
	<input type="checkbox"/> 123 Sulfide	<input type="checkbox"/> 702 Atrazine 525.2
<input type="checkbox"/> 166 Bromide		<input type="checkbox"/> 707 Simazine 525.2
<input type="checkbox"/> 34 Chloride	<input type="checkbox"/> 1243 HAB Total Microcystins	<input type="checkbox"/> SOC
<input type="checkbox"/> 1195 Bromide Chloride Ratio		<input type="checkbox"/> SOC
<input type="checkbox"/> 746 2,3,7,8-TCDD (Dioxin)	<input type="checkbox"/> 1258 HAB Cyanobacteria Screening	<input type="checkbox"/> SOC
<input type="checkbox"/> 271 PAH 525.2 or 8270		<input type="checkbox"/> SOC
<input type="checkbox"/> 124 Sulfite		<input type="checkbox"/> SOC
<input type="checkbox"/> Other	Office Use Only: <u>7</u>	
<input type="checkbox"/> Other		
<input type="checkbox"/> Other		
<input type="checkbox"/> Other		
<input type="checkbox"/> Other		
<input type="checkbox"/> Other		
		<input type="checkbox"/> 9050 MASI Use Only

N: _____ Total Containers: 1
S: _____
U: _____

Route _____

Office/Lab _____

COOLER: _____

JLS220

MW

REVISED 05-19-21 DN

C

