



7940 Memorial Drive Plain City, Ohio 43064 (614) 873-4654

Date: August 25, 2023

Whitehouse, Village Of (606)

Attn: Steve Pilcher

Po Box 2476

Whitehouse, OH 43571

RE: Certificate of Analysis for Project - Public Drinking Water

The following report contains analytical results for samples submitted on the chain of custody dated August 08, 2023.

I have reviewed the validity of the analytical data generated. All data is reported in accordance to our laboratory QA/QC plan. Any exceptions are noted in the Case Narrative or with qualifiers in the report.

If you have any questions or need additional documentation, please contact our Office.

Sincerely,

A handwritten signature in black ink that reads "Cheryl Rex". The signature is written in a cursive style and is positioned above a solid black horizontal line.

Cheryl Rex
MASI Laboratories
QA/QC Officer
cheryl@masilabs.com
(614) 873-4654



CERTIFICATE of ANALYSIS

*Microbiological/Inorganic Certification - 877
Organic Certification - 4100*

Whitehouse, Village Of
Steve Pilcher
Po Box 2476
Whitehouse, OH 43571

Client #: 606
PO Number:
Date Received: 8/8/23 12:26
Ohio EPA Analyzed Date: 8/25/23 13:08

Sampler Name: Mike Hill
Sample Date/Time: 8/8/23 06:15
Sample Monitoring Point: DS000
Sample Type: RT
Sample Tap/Address: Hydrant 6317 Finzel Rd Whitehouse OH 43571

PWSID: OH4801612 Facility ID: DS1
Repeat Sample #:
Total Chlorine (mg/L):
Free Chlorine (mg/L):
Combined Chlorine (mg/L):

Sample ID: 126420

Lab Sample # : 3H01360-01 (Potable)

Analyte	Result	Units	Qual	Reporting Limit	MDL	Date/Time Prepared	Date/Time Analyzed	Analyst	Method
---------	--------	-------	------	-----------------	-----	--------------------	--------------------	---------	--------

Disinfection Byproducts (DBP)

Chloroform	6.2	ug/L		0.5	0.02	08/10/23 19:28	08/10/23 19:28	DTS	EPA Method 524.2
Bromoform	0.7	ug/L		0.5	0.1	08/10/23 19:28	08/10/23 19:28	DTS	EPA Method 524.2
Bromodichloromethane	3.3	ug/L		0.5	0.04	08/10/23 19:28	08/10/23 19:28	DTS	EPA Method 524.2
Dibromochloromethane	2.6	ug/L		0.5	0.07	08/10/23 19:28	08/10/23 19:28	DTS	EPA Method 524.2
Total THM	12.8	ug/L		2.0	0.2	08/10/23 19:28	08/10/23 19:28	DTS	EPA Method 524.2

<i>Surrogate: 4-Bromofluorobenzene</i>	<i>88%</i>		<i>70-130</i>	<i>EPA Method 524.2</i>
<i>Surrogate: 1,2-Dichlorobenzene-d4</i>	<i>84%</i>		<i>70-130</i>	<i>EPA Method 524.2</i>



CERTIFICATE of ANALYSIS

Microbiological/Inorganic Certification - 877
Organic Certification - 4100

Whitehouse, Village Of
Steve Pilcher
Po Box 2476
Whitehouse, OH 43571

Client #: 606
PO Number:
Date Received: 8/8/23 12:26
Ohio EPA Analyzed Date: 8/25/23 13:08

Sampler Name: Mike Hill
Sample Date/Time: 8/8/23 07:36
Sample Monitoring Point: DS201
Sample Type: RT
Sample Tap/Address: Hydrant 7125 Berkey Southern Rd Whitehouse OH 43571

PWSID: OH4801612 Facility ID: DS1
Repeat Sample #:
Total Chlorine (mg/L):
Free Chlorine (mg/L):
Combined Chlorine (mg/L):

Sample ID: 155789

Lab Sample # : 3H01360-02 (Potable)

Analyte	Result	Units	Qual	Reporting Limit	MDL	Date/Time Prepared	Date/Time Analyzed	Analyst	Method	
Disinfection Byproducts (DBP)										
Monochloroacetic Acid	ND	ug/L		2.0	0.8	08/21/23 16:06	08/23/23 09:36	JRK	EPA Method 552.3	
Dichloroacetic Acid	9.3	ug/L		1.0	0.4	08/21/23 16:06	08/23/23 09:36	JRK	EPA Method 552.3	
Trichloroacetic Acid	1.7	ug/L		1.0	0.3	08/21/23 16:06	08/23/23 09:36	JRK	EPA Method 552.3	
Monobromoacetic Acid	ND	ug/L		1.0	0.5	08/21/23 16:06	08/23/23 09:36	JRK	EPA Method 552.3	
Dibromoacetic Acid	3.1	ug/L		1.0	0.5	08/21/23 16:06	08/23/23 09:36	JRK	EPA Method 552.3	
HAA 5 Total	14.1	ug/L		6.0	2.4	08/21/23 16:06	08/23/23 09:36	JRK	EPA Method 552.3	
<i>Surrogate: 2-Bromopropanoic Acid</i>			<i>97%</i>				<i>70-130</i>	<i>EPA Method 552.3</i>		
Chloroform	40.1	ug/L		0.5	0.02	08/10/23 19:52	08/10/23 19:52	DTS	EPA Method 524.2	
Bromoform	1.5	ug/L		0.5	0.1	08/10/23 19:52	08/10/23 19:52	DTS	EPA Method 524.2	
Bromodichloromethane	13.9	ug/L		0.5	0.04	08/10/23 19:52	08/10/23 19:52	DTS	EPA Method 524.2	
Dibromochloromethane	8.0	ug/L		0.5	0.07	08/10/23 19:52	08/10/23 19:52	DTS	EPA Method 524.2	
Total THM	63.5	ug/L		2.0	0.2	08/10/23 19:52	08/10/23 19:52	DTS	EPA Method 524.2	
<i>Surrogate: 4-Bromofluorobenzene</i>			<i>85%</i>				<i>70-130</i>	<i>EPA Method 524.2</i>		
<i>Surrogate: 1,2-Dichlorobenzene-d4</i>			<i>81%</i>				<i>70-130</i>	<i>EPA Method 524.2</i>		



CERTIFICATE of ANALYSIS

Microbiological/Inorganic Certification - 877

Organic Certification - 4100

Whitehouse, Village Of
 Steve Pilcher
 Po Box 2476
 Whitehouse, OH 43571

Client #: 606
 PO Number:
 Date Received: 8/8/23 12:26
 Ohio EPA Analyzed Date: 8/25/23 13:08

Sampler Name: Mike Hill
 Sample Date/Time: 8/8/23 07:08
 Sample Monitoring Point: DS000
 Sample Type: RT
 Sample Tap/Address: Hose Bib 8770 Dutch Rd Whitehouse OH 43571

PWSID: OH4801612 Facility ID: DS1
 Repeat Sample #:
 Total Chlorine (mg/L):
 Free Chlorine (mg/L):
 Combined Chlorine (mg/L):

Sample ID: 155788

Lab Sample # : 3H01360-03 (Potable)

Analyte	Result	Units	Qual	Reporting Limit	MDL	Date/Time Prepared	Date/Time Analyzed	Analyst	Method
---------	--------	-------	------	-----------------	-----	--------------------	--------------------	---------	--------

Disinfection Byproducts (DBP)

Chloroform	39.9	ug/L		0.5	0.02	08/10/23 20:16	08/10/23 20:16	DTS	EPA Method 524.2
Bromoform	1.8	ug/L		0.5	0.1	08/10/23 20:16	08/10/23 20:16	DTS	EPA Method 524.2
Bromodichloromethane	16.1	ug/L		0.5	0.04	08/10/23 20:16	08/10/23 20:16	DTS	EPA Method 524.2
Dibromochloromethane	9.2	ug/L		0.5	0.07	08/10/23 20:16	08/10/23 20:16	DTS	EPA Method 524.2
Total THM	67.0	ug/L		2.0	0.2	08/10/23 20:16	08/10/23 20:16	DTS	EPA Method 524.2

<i>Surrogate: 4-Bromofluorobenzene</i>				<i>87%</i>		<i>70-130</i>			<i>EPA Method 524.2</i>
<i>Surrogate: 1,2-Dichlorobenzene-d4</i>				<i>83%</i>		<i>70-130</i>			<i>EPA Method 524.2</i>



CERTIFICATE of ANALYSIS

Microbiological/Inorganic Certification - 877

Organic Certification - 4100

Whitehouse, Village Of
 Steve Pilcher
 Po Box 2476
 Whitehouse, OH 43571

Client #: 606
 PO Number:
 Date Received: 8/8/23 12:26
 Ohio EPA Analyzed Date: 8/25/23 13:08

Sampler Name: Mike Hill
 Sample Date/Time: 8/8/23 06:52
 Sample Monitoring Point: DS202
 Sample Type: RT
 Sample Tap/Address: Hydrant 426 8911 Dutch Rd Whitehouse OH 43571

PWSID: OH4801612 Facility ID: DS1
 Repeat Sample #:
 Total Chlorine (mg/L):
 Free Chlorine (mg/L):
 Combined Chlorine (mg/L):

Sample ID: 126423

Lab Sample # : 3H01360-04 (Potable)

Analyte	Result	Units	Qual	Reporting Limit	MDL	Date/Time Prepared	Date/Time Analyzed	Analyst	Method
---------	--------	-------	------	-----------------	-----	--------------------	--------------------	---------	--------

Disinfection Byproducts (DBP)

Monochloroacetic Acid	ND	ug/L		2.0	0.8	08/21/23 16:06	08/23/23 10:00	JRK	EPA Method 552.3
Dichloroacetic Acid	6.8	ug/L		1.0	0.4	08/21/23 16:06	08/23/23 10:00	JRK	EPA Method 552.3
Trichloroacetic Acid	ND	ug/L		1.0	0.3	08/21/23 16:06	08/23/23 10:00	JRK	EPA Method 552.3
Monobromoacetic Acid	ND	ug/L		1.0	0.5	08/21/23 16:06	08/23/23 10:00	JRK	EPA Method 552.3
Dibromoacetic Acid	2.7	ug/L		1.0	0.5	08/21/23 16:06	08/23/23 10:00	JRK	EPA Method 552.3
HAA 5 Total	9.5	ug/L		6.0	2.4	08/21/23 16:06	08/23/23 10:00	JRK	EPA Method 552.3
<hr style="border-top: 1px dashed #000;"/>									
<i>Surrogate: 2-Bromopropanoic Acid</i>				<i>105%</i>		<i>70-130</i>			<i>EPA Method 552.3</i>
Chloroform	40.1	ug/L		0.5	0.02	08/10/23 20:39	08/10/23 20:39	DTS	EPA Method 524.2
Bromoform	1.7	ug/L		0.5	0.1	08/10/23 20:39	08/10/23 20:39	DTS	EPA Method 524.2
Bromodichloromethane	16.4	ug/L		0.5	0.04	08/10/23 20:39	08/10/23 20:39	DTS	EPA Method 524.2
Dibromochloromethane	9.3	ug/L		0.5	0.07	08/10/23 20:39	08/10/23 20:39	DTS	EPA Method 524.2
Total THM	67.5	ug/L		2.0	0.2	08/10/23 20:39	08/10/23 20:39	DTS	EPA Method 524.2
<hr style="border-top: 1px dashed #000;"/>									
<i>Surrogate: 4-Bromofluorobenzene</i>				<i>85%</i>		<i>70-130</i>			<i>EPA Method 524.2</i>
<i>Surrogate: 1,2-Dichlorobenzene-d4</i>				<i>82%</i>		<i>70-130</i>			<i>EPA Method 524.2</i>

The contents of this report apply to the sample(s) analyzed in accordance with the chain of custody document.
 No duplication of this report is allowed, except in its entirety.



CERTIFICATE of ANALYSIS

Microbiological/Inorganic Certification - 877

Organic Certification - 4100

Whitehouse, Village Of
 Steve Pilcher
 Po Box 2476
 Whitehouse, OH 43571

Client #: 606
 PO Number:
 Date Received: 8/8/23 12:26
 Ohio EPA Analyzed Date: 8/25/23 13:08

Sampler Name: Mike Hill
 Sample Date/Time: 8/8/23 06:00
 Sample Monitoring Point: EP001
 Sample Type: RT
 Sample Tap/Address: Sink 6010 N. Texas St Whitehouse OH 43571

PWSID: OH4801612 Facility ID: 4855849
 Repeat Sample #:
 Total Chlorine (mg/L):
 Free Chlorine (mg/L):
 Combined Chlorine (mg/L):

Sample ID: 126422

Lab Sample # : 3H01360-05 (Potable)

Analyte	Result	Units	Qual	Reporting Limit	MDL	Date/Time Prepared	Date/Time Analyzed	Analyst	Method
---------	--------	-------	------	-----------------	-----	--------------------	--------------------	---------	--------

Disinfection Byproducts (DBP)

Monochloroacetic Acid	No Analyze	ug/L	LCS, X	2.0	0.8	08/17/23 07:40	08/24/23 14:09	KJT	EPA Method 552.3
Dichloroacetic Acid	No Analyze	ug/L	LCS, X	1.0	0.4	08/17/23 07:40	08/24/23 14:09	KJT	EPA Method 552.3
Trichloroacetic Acid	No Analyze	ug/L	LCS, X	1.0	0.3	08/17/23 07:40	08/24/23 14:09	KJT	EPA Method 552.3
Monobromoacetic Acid	No Analyze	ug/L	LCS, X	1.0	0.5	08/17/23 07:40	08/24/23 14:09	KJT	EPA Method 552.3
Dibromoacetic Acid	No Analyze	ug/L	LCS, X	1.0	0.5	08/17/23 07:40	08/24/23 14:09	KJT	EPA Method 552.3
HAA 5 Total	No Analyze	ug/L	LCS, X	6.0	2.4	08/17/23 07:40	08/24/23 14:09	KJT	EPA Method 552.3
<i>Surrogate: 2-Bromopropanoic Acid</i>			<i>% LCS, X</i>			<i>70-130</i>			<i>EPA Method 552.3</i>
Chloroform	41.8	ug/L		0.5	0.02	08/10/23 21:02	08/10/23 21:02	DTS	EPA Method 524.2
Bromoform	1.7	ug/L		0.5	0.1	08/10/23 21:02	08/10/23 21:02	DTS	EPA Method 524.2
Bromodichloromethane	16.4	ug/L		0.5	0.04	08/10/23 21:02	08/10/23 21:02	DTS	EPA Method 524.2
Dibromochloromethane	9.4	ug/L		0.5	0.07	08/10/23 21:02	08/10/23 21:02	DTS	EPA Method 524.2
Total THM	69.4	ug/L		2.0	0.2	08/10/23 21:02	08/10/23 21:02	DTS	EPA Method 524.2
<i>Surrogate: 4-Bromofluorobenzene</i>			<i>87%</i>			<i>70-130</i>			<i>EPA Method 524.2</i>
<i>Surrogate: 1,2-Dichlorobenzene-d4</i>			<i>86%</i>			<i>70-130</i>			<i>EPA Method 524.2</i>

The contents of this report apply to the sample(s) analyzed in accordance with the chain of custody document. No duplication of this report is allowed, except in its entirety.



CERTIFICATE of ANALYSIS

*Microbiological/Inorganic Certification - 877
Organic Certification - 4100*

Whitehouse, Village Of
Steve Pilcher
Po Box 2476
Whitehouse, OH 43571

Client #: 606
PO Number:
Date Received: 8/8/23 12:26
Ohio EPA Analyzed Date: 8/25/23 13:08

Sampler Name: Mike Hill
Sample Date/Time: 8/8/23 07:23
Sample Monitoring Point: DS000
Sample Type: RT
Sample Tap/Address: Hose Bib 6763 Gilead St Whitehouse OH 43571

PWSID: OH4801612 Facility ID: DS1
Repeat Sample #:
Total Chlorine (mg/L):
Free Chlorine (mg/L):
Combined Chlorine (mg/L):

Sample ID: 126421

Lab Sample # : 3H01360-06 (Potable)

Analyte	Result	Units	Qual	Reporting Limit	MDL	Date/Time Prepared	Date/Time Analyzed	Analyst	Method
---------	--------	-------	------	-----------------	-----	--------------------	--------------------	---------	--------

Disinfection Byproducts (DBP)

Chloroform	9.6	ug/L		0.5	0.02	08/10/23 21:25	08/10/23 21:25	DTS	EPA Method 524.2
Bromoform	1.0	ug/L		0.5	0.1	08/10/23 21:25	08/10/23 21:25	DTS	EPA Method 524.2
Bromodichloromethane	5.1	ug/L		0.5	0.04	08/10/23 21:25	08/10/23 21:25	DTS	EPA Method 524.2
Dibromochloromethane	4.0	ug/L		0.5	0.07	08/10/23 21:25	08/10/23 21:25	DTS	EPA Method 524.2
Total THM	19.8	ug/L		2.0	0.2	08/10/23 21:25	08/10/23 21:25	DTS	EPA Method 524.2
<hr style="border-top: 1px dashed black;"/>									
<i>Surrogate: 4-Bromofluorobenzene</i>				<i>87%</i>		<i>70-130</i>			<i>EPA Method 524.2</i>
<i>Surrogate: 1,2-Dichlorobenzene-d4</i>				<i>86%</i>		<i>70-130</i>			<i>EPA Method 524.2</i>

*The contents of this report apply to the sample(s) analyzed in accordance with the chain of custody document.
No duplication of this report is allowed, except in its entirety.*



CERTIFICATE of ANALYSIS

Microbiological/Inorganic Certification - 877

Organic Certification - 4100

Whitehouse, Village Of
 Steve Pilcher
 Po Box 2476
 Whitehouse, OH 43571

Client #: 606
 PO Number:
 Date Received: 8/8/23 12:26
 Ohio EPA Analyzed Date: 8/25/23 13:08

Notes and Definitions

Item	Definition
J	Analyte was positively identified, the associated numerical value is estimated.
LCS	LCS/LCD Failure
X	Sample was not analyzed due to a process deviation and will not be reported to the Ohio EPA.
mg/kg Dry	Sample results reported on a dry weight basis
ug/L	ppb/Part per Billion
mg/L	ppm/Part per Million
ng/L	ppt/Part per Trillion
ND	Analyte NOT DETECTED at or above the method detection limit (MDL)
!	Analyte is at or above the Maximum Contaminate Level
MDL	Method Detection Limit
CFU	Colony Forming Units
MPN	Most Probable Number
NTU	Nephelometric Turbidity Unit
pCi/L	Picocuries per liter
SVI	Sludge Volume Index
RPD	Relative Percent Difference
%REC	Percent Recovery
Source	Sample that was matrix spiked or duplicated.

- Notes:
1. Calculated analytes are based on raw data and may not reflect the rounding of the individual compounds.
 2. Samples are analyzed using the information received on the request sheet and may not be analyzed when the parameters fall outside required guidelines.



7940 Memorial Drive
Plain City, OH 43084
614-873-4654

3H01360-01

AR # 126420
Received: 8/8/2023
Matrix: Potable

Request Sheet

Appear on Bottle: 126420
S information **

Project Name: _____

Client #: 606 Client Name: Village of Whitehouse County: Lucas P.O.# _____

Sampler Name: Mike Hill SMP ID: DS000 Sample Type: Compliance (C)
 New Well (N)
 Special/Other (O)

Sample Tap: Hydrant Date Collected: 08/08/23 Time Collected: 06:35 am
(MM/DD/YY) (hh:mm am/pm)

Tap Address: 6317 Finzel Rd., Whitehouse, Oh. 43571

Public Sample PWS ID #: 4801612 Facility ID #: DS1 Private Sample

Non-Preserved Parameters	Misc. Parameters & Preservatives	SOC Parameter Groups
<input type="checkbox"/> 183 Asbestos	<input type="checkbox"/> 154 VOC (Ascorbic Acid/HCL) 524.2	<input type="checkbox"/> 900 GROUP 1 Method 525.2
<input type="checkbox"/> 158 Total (Gross) Alpha	<input checked="" type="checkbox"/> 213 TTHM (Ascorbic Acid/HCL) 524.2	<input type="checkbox"/> 899 GROUP 2 Method 515.3
<input type="checkbox"/> 159 Total (Gross) Beta	<input type="checkbox"/> 375 HAA5 (NH4CL) 552.3	<input type="checkbox"/> 903 GROUP 2 Method 531.1
<input type="checkbox"/> 254 Radium 228	<input type="checkbox"/> 171 Toluene 524.2 or 8260	<input type="checkbox"/> 898 GROUP 3 Method 508
	<input type="checkbox"/> 174 BTEX (Ascorbic Acid/HCL)	<input type="checkbox"/> 904 GROUP 3 Method 547
	<input type="checkbox"/> 317 Lithium	<input type="checkbox"/> 905 GROUP 3 Method 549.2
<input type="checkbox"/> 371 UV254	<input type="checkbox"/> 134 Titanium	<input type="checkbox"/> 900 GROUP 4 Method 525.2
<input type="checkbox"/> 354 DOC	<input type="checkbox"/> 157 Total Organic Halogens	<input type="checkbox"/> 901 GROUP 4 Method 548.1
<input type="checkbox"/> 1080 SUVA	<input type="checkbox"/> 366 Hydrogen Sulfide	<input type="checkbox"/> 701 Alachlor 525.2
	<input type="checkbox"/> 123 Sulfide	<input type="checkbox"/> 702 Atrazine 525.2
<input type="checkbox"/> 166 Bromide		<input type="checkbox"/> 707 Simazine 525.2
<input type="checkbox"/> 34 Chloride	<input type="checkbox"/> 1243 HAB Total Microcystins	<input type="checkbox"/> SOC
<input type="checkbox"/> 1195 Bromide Chloride Ratio		<input type="checkbox"/> SOC
<input type="checkbox"/> 746 2,3,7,8-TCDD (Dioxin)	<input type="checkbox"/> 1258 HAB Cyanobacteria Screening	<input type="checkbox"/> SOC
<input type="checkbox"/> 271 PAH 525.2 or 8270		<input type="checkbox"/> SOC
<input type="checkbox"/> 124 Sulfite		<input type="checkbox"/> SOC
<input type="checkbox"/> Other	Office Use Only: <u>8</u>	
<input type="checkbox"/> Other		
<input type="checkbox"/> Other		
<input type="checkbox"/> Other		
<input type="checkbox"/> Other		
		<input type="checkbox"/> 9050 MASI Use Only

N: _____ Total Containers: 1
S: _____
U: _____

Route: JLS 220

Office/Lab: CO

COOLER: _____ Revised 10-18-22 DN



7940 Memorial Drive
Plain City, OH 43064
614-873-4654

C 3H01360-02
AR # 155789
Received: 8/8/2023
Matrix: Potable
Analyte: **** S**

Request Sheet
Appear on Bottle: 155789
Information *:

Project Name: _____

Client #: 6006 Client Name: Village of Whitehouse County: Lucas P.O.# _____

Sampler Name: Mike Hill SMP ID: DS201 Sample Type: Compliance (C)
 New Well (N)
 Special/Other (O)

Sample Tap: Hydrant Date Collected: 08/08/23 Time Collected: 07:36 am
(MM/DD/YY) (hh:mm am/pm)

Tap Address: 7125 Berkey Southern Rd., Whitehouse, Oh. 43571

Public Sample PWS ID #: 4801612 Facility ID #: DS1 Private Sample

Non-Preserved Parameters	Misc. Parameters & Preservatives	SOC Parameter Groups
<input type="checkbox"/> 183 Asbestos	<input type="checkbox"/> 154 VOC (Ascorbic Acid/HCL) 524.2	<input type="checkbox"/> 900 GROUP 1 Method 525.2
<input type="checkbox"/> 158 Total (Gross) Alpha	<input checked="" type="checkbox"/> 213 TTHM (Ascorbic Acid/HCL) 524.2	<input type="checkbox"/> 899 GROUP 2 Method 515.3
<input type="checkbox"/> 159 Total (Gross) Beta	<input checked="" type="checkbox"/> 375 HAA5 (NH4CL) 552.3	<input type="checkbox"/> 903 GROUP 2 Method 531.1
<input type="checkbox"/> 254 Radium 228	<input type="checkbox"/> 171 Toluene 524.2 or 8260	<input type="checkbox"/> 898 GROUP 3 Method 508
	<input type="checkbox"/> 174 BTEX (Ascorbic Acid/HCL)	<input type="checkbox"/> 904 GROUP 3 Method 547
	<input type="checkbox"/> 317 Lithium	<input type="checkbox"/> 905 GROUP 3 Method 549.2
<input type="checkbox"/> 371 UV254	<input type="checkbox"/> 134 Titanium	<input type="checkbox"/> 900 GROUP 4 Method 525.2
<input type="checkbox"/> 354 DOC	<input type="checkbox"/> 157 Total Organic Halogens	<input type="checkbox"/> 901 GROUP 4 Method 548.1
<input type="checkbox"/> 1080 SUVA	<input type="checkbox"/> 366 Hydrogen Sulfide	<input type="checkbox"/> 701 Alachlor 525.2
	<input type="checkbox"/> 123 Sulfide	<input type="checkbox"/> 702 Atrazine 525.2
<input type="checkbox"/> 166 Bromide		<input type="checkbox"/> 707 Simazine 525.2
<input type="checkbox"/> 34 Chloride	<input type="checkbox"/> 1243 HAB Total Microcystins	<input type="checkbox"/> SOC
<input type="checkbox"/> 1195 Bromide Chloride Ratio		<input type="checkbox"/> SOC
<input type="checkbox"/> 746 2,3,7,8-TCDD (Dioxin)	<input type="checkbox"/> 1258 HAB Cyanobacteria Screening	<input type="checkbox"/> SOC
<input type="checkbox"/> 271 PAH 525.2 or 8270		<input type="checkbox"/> SOC
<input type="checkbox"/> 124 Sulfite		<input type="checkbox"/> SOC
<input type="checkbox"/> Other	<div style="border: 1px solid black; padding: 5px;"> Office Use Only: <u>8</u> _____ _____ _____ _____ _____ </div>	
<input type="checkbox"/> Other		
<input type="checkbox"/> Other		
<input type="checkbox"/> Other		
<input type="checkbox"/> Other		
<input type="checkbox"/> Other		
		<input type="checkbox"/> 9050 MASI Use Only

N: _____ Total Containers: 1
S: _____
U: _____

Route: _____
Office/Lab: CO

COOLER: _____ Revised 10-18-22 DN



3H01360-03

AR # 155788
 Received: 8/8/2023
 Matrix: Potable

Request Sheet

Appear on Bottle: 155788

Information *

Project Name: _____

Client #: 606 Client Name: Village of Whitehouse County: Lucas P.O.# _____

Sampler Name: Mike Hill SMP ID: DS000 Sample Type: Compliance (C)
 New Well (N)
 Special/Other (O)

Sample Tap: Hose bib Date Collected: 08/08/23 Time Collected: 07:08 am
 (MM/DD/YY) (hh:mm am/pm)

Tap Address: 8770 Dutch Rd., Whitehouse, Oh. 43571

Public Sample PWS ID #: 4801612 Facility ID #: DS1 Private Sample

Non-Preserved Parameters	Misc. Parameters & Preservatives	SOC Parameter Groups
<input type="checkbox"/> 183 Asbestos	<input type="checkbox"/> 154 VOC (Ascorbic Acid/HCL) 524.2	<input type="checkbox"/> 900 GROUP 1 Method 525.2
<input type="checkbox"/> 158 Total (Gross) Alpha	<input checked="" type="checkbox"/> 213 TTHM (Ascorbic Acid/HCL) 524.2	<input type="checkbox"/> 899 GROUP 2 Method 515.3
<input type="checkbox"/> 159 Total (Gross) Beta	<input type="checkbox"/> 375 HAA5 (NH4CL) 552.3	<input type="checkbox"/> 903 GROUP 2 Method 531.1
<input type="checkbox"/> 254 Radium 228	<input type="checkbox"/> 171 Toluene 524.2 or 8260	<input type="checkbox"/> 898 GROUP 3 Method 508
	<input type="checkbox"/> 174 BTEX (Ascorbic Acid/HCL)	<input type="checkbox"/> 904 GROUP 3 Method 547
	<input type="checkbox"/> 317 Lithium	<input type="checkbox"/> 905 GROUP 3 Method 549.2
<input type="checkbox"/> 371 UV254	<input type="checkbox"/> 134 Titanium	<input type="checkbox"/> 900 GROUP 4 Method 525.2
<input type="checkbox"/> 354 DOC	<input type="checkbox"/> 157 Total Organic Halogens	<input type="checkbox"/> 901 GROUP 4 Method 548.1
<input type="checkbox"/> 1080 SUVA	<input type="checkbox"/> 366 Hydrogen Sulfide	<input type="checkbox"/> 701 Alachlor 525.2
	<input type="checkbox"/> 123 Sulfide	<input type="checkbox"/> 702 Atrazine 525.2
<input type="checkbox"/> 166 Bromide		<input type="checkbox"/> 707 Simazine 525.2
<input type="checkbox"/> 34 Chloride	<input type="checkbox"/> 1243 HAB Total Microcystins	<input type="checkbox"/> SOC
<input type="checkbox"/> 1195 Bromide Chloride Ratio		<input type="checkbox"/> SOC
<input type="checkbox"/> 746 2,3,7,8-TCDD (Dioxin)	<input type="checkbox"/> 1258 HAB Cyanobacteria Screening	<input type="checkbox"/> SOC
<input type="checkbox"/> 271 PAH 525.2 or 8270		<input type="checkbox"/> SOC
<input type="checkbox"/> 124 Sulfite		<input type="checkbox"/> SOC
<input type="checkbox"/> Other	<div style="border: 1px solid black; padding: 5px;"> Office Use Only: <u>8</u> _____ _____ _____ _____ _____ </div>	
<input type="checkbox"/> Other		
<input type="checkbox"/> Other		
<input type="checkbox"/> Other		
<input type="checkbox"/> Other		
<input type="checkbox"/> Other		
		<input type="checkbox"/> 9050 MASI Use Only

N: _____ Total Containers: 1
 S: _____
 U: _____

Route: _____
 Office/Lab: CO

COOLER: _____ Revised 10-18-22 DN



ENVIRONMENTAL LABORATORIES

7940 Memorial Drive
Plain City, OH 43064
614-873-4654

3H01360-04

AR # 126423
Received: 8/8/2023
Matrix: Potable

Request Sheet

Appear on Bottle: 126423
IS information **

Project Name: _____

Client #: 606 Client Name: Village of Whitehouse County: Lucas P.O.# _____

Sampler Name: Mike Hill SMP ID: DS202 Sample Type: Compliance (C)
 New Well (N)
 Special/Other (O)

Sample Tap: Hydrant #426 Date Collected: 08/08/23 Time Collected: 06:52 am
(MM/DD/YY) (hh:mm am/pm)

Tap Address: 8911 Dutch Rd., Whitehouse, Oh. 43571

Public Sample PWS ID #: 4801612 Facility ID #: DS1 Private Sample

Non-Preserved Parameters	Misc. Parameters & Preservatives	SOC Parameter Groups
<input type="checkbox"/> 183 Asbestos	<input type="checkbox"/> 154 VOC (Ascorbic Acid/HCL) 524.2	<input type="checkbox"/> 900 GROUP 1 Method 525.2
<input type="checkbox"/> 158 Total (Gross) Alpha	<input checked="" type="checkbox"/> 213 TTHM (Ascorbic Acid/HCL) 524.2	<input type="checkbox"/> 899 GROUP 2 Method 515.3
<input type="checkbox"/> 159 Total (Gross) Beta	<input checked="" type="checkbox"/> 375 HAA5 (NH4CL) 552.3	<input type="checkbox"/> 903 GROUP 2 Method 531.1
<input type="checkbox"/> 254 Radium 228	<input type="checkbox"/> 171 Toluene 524.2 or 8260	<input type="checkbox"/> 898 GROUP 3 Method 508
	<input type="checkbox"/> 174 BTEX (Ascorbic Acid/HCL)	<input type="checkbox"/> 904 GROUP 3 Method 547
	<input type="checkbox"/> 317 Lithium	<input type="checkbox"/> 905 GROUP 3 Method 549.2
<input type="checkbox"/> 371 UV254	<input type="checkbox"/> 134 Titanium	<input type="checkbox"/> 900 GROUP 4 Method 525.2
<input type="checkbox"/> 354 DOC	<input type="checkbox"/> 157 Total Organic Halogens	<input type="checkbox"/> 901 GROUP 4 Method 548.1
<input type="checkbox"/> 1080 SUVA	<input type="checkbox"/> 366 Hydrogen Sulfide	<input type="checkbox"/> 701 Alachlor 525.2
	<input type="checkbox"/> 123 Sulfide	<input type="checkbox"/> 702 Atrazine 525.2
<input type="checkbox"/> 166 Bromide		<input type="checkbox"/> 707 Simazine 525.2
<input type="checkbox"/> 34 Chloride	<input type="checkbox"/> 1243 HAB Total Microcystins	<input type="checkbox"/> SOC
<input type="checkbox"/> 1195 Bromide Chloride Ratio		<input type="checkbox"/> SOC
<input type="checkbox"/> 746 2,3,7,8-TCDD (Dioxin)	<input type="checkbox"/> 1258 HAB Cyanobacteria Screening	<input type="checkbox"/> SOC
<input type="checkbox"/> 271 PAH 525.2 or 8270		<input type="checkbox"/> SOC
<input type="checkbox"/> 124 Sulfite		<input type="checkbox"/> SOC
<input type="checkbox"/> Other	Office Use Only: <u>8</u>	
<input type="checkbox"/> Other		
<input type="checkbox"/> Other		
<input type="checkbox"/> Other		
<input type="checkbox"/> Other		
<input type="checkbox"/> Other		
		<input type="checkbox"/> 9050 MASI Use Only

N: _____ Total Containers: 1
S: _____
U: _____

Route: _____ TL5 220
Office/Lab: _____ CO

COOLER:

Revised 10-18-22 DN



C
3H01360-05
 Anal: AR # 126422
 Received: 8/8/2023
 ** S: Matrix: Potable

Test Sheet
 Sample on Bottle: 126422
 Information **

Project Name: _____
 Client #: 606 Client Name: Village of Whitehouse County: Lucas P.O.#: _____
 Sampler Name: Mike Hill SMP ID: EP001 Sample Type: Compliance (C)
 New Well (N)
 Special/Other (O)
 Sample Tap: Sink Date Collected: 08/08/23 Time Collected: 06:00 am
 (MM/DD/YY) (hh:mm am/pm)
 Tap Address: 6010 N. Texas St., Whitehouse, Oh. 43571

Public Sample PWS ID #: 4801612 Facility ID #: 4855849 Private Sample
 STU ID #

Non-Preserved Parameters	Misc. Parameters & Preservatives	SOC Parameter Groups
<input type="checkbox"/> 183 Asbestos	<input type="checkbox"/> 154 VOC (Ascorbic Acid/HCL) 524.2	<input type="checkbox"/> 900 GROUP 1 Method 525.2
<input type="checkbox"/> 158 Total (Gross) Alpha	<input checked="" type="checkbox"/> 213 TTHM (Ascorbic Acid/HCL) 524.2	<input type="checkbox"/> 899 GROUP 2 Method 515.3
<input type="checkbox"/> 159 Total (Gross) Beta	<input checked="" type="checkbox"/> 375 HAA5 (NH4CL) 552.3	<input type="checkbox"/> 903 GROUP 2 Method 531.1
<input type="checkbox"/> 254 Radium 228	<input type="checkbox"/> 171 Toluene 524.2 or 8260	<input type="checkbox"/> 898 GROUP 3 Method 508
	<input type="checkbox"/> 174 BTEX (Ascorbic Acid/HCL)	<input type="checkbox"/> 904 GROUP 3 Method 547
	<input type="checkbox"/> 317 Lithium	<input type="checkbox"/> 905 GROUP 3 Method 549.2
<input type="checkbox"/> 371 UV254	<input type="checkbox"/> 134 Titanium	<input type="checkbox"/> 900 GROUP 4 Method 525.2
<input type="checkbox"/> 354 DOC	<input type="checkbox"/> 157 Total Organic Halogens	<input type="checkbox"/> 901 GROUP 4 Method 548.1
<input type="checkbox"/> 1080 SUVA	<input type="checkbox"/> 366 Hydrogen Sulfide	<input type="checkbox"/> 701 Alachlor 525.2
	<input type="checkbox"/> 123 Sulfide	<input type="checkbox"/> 702 Atrazine 525.2
<input type="checkbox"/> 166 Bromide		<input type="checkbox"/> 707 Simazine 525.2
<input type="checkbox"/> 34 Chloride	<input type="checkbox"/> 1243 HAB Total Microcystins	<input type="checkbox"/> SOC
<input type="checkbox"/> 1195 Bromide Chloride Ratio		<input type="checkbox"/> SOC
<input type="checkbox"/> 746 2,3,7,8-TCDD (Dioxin)	<input type="checkbox"/> 1258 HAB Cyanobacteria Screening	<input type="checkbox"/> SOC
<input type="checkbox"/> 271 PAH 525.2 or 8270		<input type="checkbox"/> SOC
<input type="checkbox"/> 124 Sulfite		<input type="checkbox"/> SOC
<input type="checkbox"/> Other	<div style="border: 1px solid black; padding: 5px;"> Office Use Only: <u>8</u> _____ _____ _____ _____ _____ </div>	
<input type="checkbox"/> Other		
<input type="checkbox"/> Other		
<input type="checkbox"/> Other		
<input type="checkbox"/> Other		
<input type="checkbox"/> Other		
		<input type="checkbox"/> 9050 MASI Use Only

N: _____ Total Containers: 1
 S: _____
 U: _____

Route: JLS 220
 Office/Lab: CO
 COOLER: _____ Revised 10-18-22 DN
 Page 13 of 14



7940 Memorial Drive
Plain City, OH 43084
614-873-4654

Chemi

Analysis Req

** See reve

Potable Water

3H01360-06

AR # 126421

Received: 8/8/2023

Matrix: Potable

Sheet

Bottle: 126421

tion *

Project Name: _____

Client #: 606 Client Name: Village of Whitehouse County: Lucas P.O.# _____

Sampler Name: Mike Hill SMP ID: DS000 Sample Type: Compliance (C)
 New Well (N)
 Special/Other (O)

Sample Tap: Hose bib Date Collected: 08/08/23 Time Collected: 07:23am
(MM/DD/YY) (hh:mm am/pm)

Tap Address: 6763 Gilead St., Whitehouse, Oh. 43571

Public Sample PWS ID #: 4801612 Facility ID #: DS1 Private Sample

Non-Preserved Parameters	Misc. Parameters & Preservatives	SOC Parameter Groups
<input type="checkbox"/> 183 Asbestos	<input type="checkbox"/> 154 VOC (Ascorbic Acid/HCL) 524.2	<input type="checkbox"/> 900 GROUP 1 Method 525.2
<input type="checkbox"/> 158 Total (Gross) Alpha	<input checked="" type="checkbox"/> 213 TTHM (Ascorbic Acid/HCL) 524.2	<input type="checkbox"/> 899 GROUP 2 Method 515.3
<input type="checkbox"/> 159 Total (Gross) Beta	<input type="checkbox"/> 375 HAA5 (NH4CL) 552.3	<input type="checkbox"/> 903 GROUP 2 Method 531.1
<input type="checkbox"/> 254 Radium 228	<input type="checkbox"/> 171 Toluene 524.2 or 8260	<input type="checkbox"/> 898 GROUP 3 Method 508
	<input type="checkbox"/> 174 BTEX (Ascorbic Acid/HCL)	<input type="checkbox"/> 904 GROUP 3 Method 547
	<input type="checkbox"/> 317 Lithium	<input type="checkbox"/> 905 GROUP 3 Method 549.2
<input type="checkbox"/> 371 UV254	<input type="checkbox"/> 134 Titanium	<input type="checkbox"/> 900 GROUP 4 Method 525.2
<input type="checkbox"/> 354 DOC	<input type="checkbox"/> 157 Total Organic Halogens	<input type="checkbox"/> 901 GROUP 4 Method 548.1
<input type="checkbox"/> 1080 SUVA	<input type="checkbox"/> 366 Hydrogen Sulfide	<input type="checkbox"/> 701 Alachlor 525.2
	<input type="checkbox"/> 123 Sulfide	<input type="checkbox"/> 702 Atrazine 525.2
<input type="checkbox"/> 166 Bromide		<input type="checkbox"/> 707 Simazine 525.2
<input type="checkbox"/> 34 Chloride	<input type="checkbox"/> 1243 HAB Total Microcystins	<input type="checkbox"/> SOC
<input type="checkbox"/> 1195 Bromide Chloride Ratio		<input type="checkbox"/> SOC
<input type="checkbox"/> 746 2,3,7,8-TCDD (Dioxin)	<input type="checkbox"/> 1258 HAB Cyanobacteria Screening	<input type="checkbox"/> SOC
<input type="checkbox"/> 271 PAH 525.2 or 8270		<input type="checkbox"/> SOC
<input type="checkbox"/> 124 Sulfite		<input type="checkbox"/> SOC
<input type="checkbox"/> Other	Office Use Only: <u>8</u>	
<input type="checkbox"/> Other		
<input type="checkbox"/> Other		
<input type="checkbox"/> Other		
<input type="checkbox"/> Other		
		<input checked="" type="checkbox"/> 9050 MASI Use Only

N: _____ Total Containers: 1
S: _____
U: _____

Route: _____ 125220
Office/Lab: _____ CO

COOLER: _____ Revised 10-18-22 DN