



7940 Memorial Drive Plain City, Ohio 43064 (614) 873-4654

Date: August 26, 2025

Whitehouse, Village Of (606)

Attn: Mike Hill

Po Box 2476

Whitehouse, OH 43571

RE: Certificate of Analysis for Project - Public Drinking Water

The following report contains analytical results for samples submitted on the chain of custody dated August 12, 2025.

I have reviewed the validity of the analytical data generated. All data is reported in accordance to our laboratory QA/QC plan. Any exceptions are noted in the Case Narrative or with qualifiers in the report.

If you have any questions or need additional documentation, please contact our Office.

Sincerely,

A handwritten signature in black ink that reads "Cheryl Rex". The signature is written in a cursive style and is positioned above a solid black horizontal line.

Cheryl Rex
MASI Laboratories
QA/QC Officer
cheryl@masilabs.com
(614) 873-4654



CERTIFICATE of ANALYSIS

Microbiological/Inorganic Certification - 877

Organic Certification - 4100

Whitehouse, Village Of
Mike Hill
Po Box 2476
Whitehouse, OH 43571

Client #: 606
PO Number:
Date Received: 8/12/25 12:11
Ohio EPA Analyzed Date: 8/26/25 12:14

Sampler Name: Matt Braun
Sample Date/Time: 8/11/25 14:15
Sample Monitoring Point: EP001
Sample Type: SP
Sample Tap/Address: Hose Bib, 6010 N Texas St Whitehouse OH 43571

PWSID: OH4801612 Facility ID: 4855849
Repeat Sample #:
Total Chlorine (mg/L):
Free Chlorine (mg/L):
Combined Chlorine (mg/L):

Sample ID: 346405

Lab Sample # : 5H01776-01 (Potable)

Analyte	Result	Units	Qual	Reporting Limit	MDL	Date/Time Prepared	Date/Time Analyzed	Analyst	Method
---------	--------	-------	------	-----------------	-----	--------------------	--------------------	---------	--------

Disinfection Byproducts (DBP)

Monochloroacetic Acid	ND	ug/L		2.0	0.6	08/21/25 08:02	08/21/25 22:45	JRK	EPA Method 552.3
Dichloroacetic Acid	5.6	ug/L		1.0	0.5	08/21/25 08:02	08/21/25 22:45	JRK	EPA Method 552.3
Trichloroacetic Acid	ND	ug/L		1.0	0.7	08/21/25 08:02	08/21/25 22:45	JRK	EPA Method 552.3
Monobromoacetic Acid	ND	ug/L		1.0	0.5	08/21/25 08:02	08/21/25 22:45	JRK	EPA Method 552.3
Dibromoacetic Acid	2.3	ug/L		1.0	0.6	08/21/25 08:02	08/21/25 22:45	JRK	EPA Method 552.3
HAA 5 Total	7.9	ug/L		6.0	2.8	08/21/25 08:02	08/21/25 22:45	JRK	EPA Method 552.3
Surrogate: 2-Bromopropanoic Acid			113%			70-130			EPA Method 552.3
Chloroform	32.9	ug/L		0.5	0.07	08/15/25 19:24	08/15/25 19:24	DTS	EPA Method 524.2
Bromoform	1.7	ug/L		0.5	0.06	08/15/25 19:24	08/15/25 19:24	DTS	EPA Method 524.2
Bromodichloromethane	14.0	ug/L		0.5	0.07	08/15/25 19:24	08/15/25 19:24	DTS	EPA Method 524.2
Dibromochloromethane	8.2	ug/L		0.5	0.08	08/15/25 19:24	08/15/25 19:24	DTS	EPA Method 524.2
Total THM	56.8	ug/L		2.0	0.3	08/15/25 19:24	08/15/25 19:24	DTS	EPA Method 524.2
Surrogate: 4-Bromofluorobenzene			77%			70-130			EPA Method 524.2
Surrogate: 1,2-Dichlorobenzene-d4			83%			70-130			EPA Method 524.2

The contents of this report apply to the sample(s) analyzed in accordance with the chain of custody document.
No duplication of this report is allowed, except in its entirety.



CERTIFICATE of ANALYSIS

Microbiological/Inorganic Certification - 877

Organic Certification - 4100

Whitehouse, Village Of
Mike Hill
Po Box 2476
Whitehouse, OH 43571

Client #: 606
PO Number:
Date Received: 8/12/25 12:11
Ohio EPA Analyzed Date: 8/26/25 12:14

Sampler Name: Matt Braun
Sample Date/Time: 8/11/25 13:50
Sample Monitoring Point: DS000
Sample Type: SP
Sample Tap/Address: Hydrant 6763 Gilead St., Whitehouse OH 43571

PWSID: OH4801612 Facility ID: DS1
Repeat Sample #:
Total Chlorine (mg/L):
Free Chlorine (mg/L):
Combined Chlorine (mg/L):

Sample ID: 346404

Lab Sample # : 5H01776-02 (Potable)

Analyte	Result	Units	Qual	Reporting Limit	MDL	Date/Time Prepared	Date/Time Analyzed	Analyst	Method
---------	--------	-------	------	-----------------	-----	--------------------	--------------------	---------	--------

Disinfection Byproducts (DBP)

Chloroform	16.6	ug/L		0.5	0.07	08/15/25 19:49	08/15/25 19:49	DTS	EPA Method 524.2
Bromoform	1.2	ug/L		0.5	0.06	08/15/25 19:49	08/15/25 19:49	DTS	EPA Method 524.2
Bromodichloromethane	7.5	ug/L		0.5	0.07	08/15/25 19:49	08/15/25 19:49	DTS	EPA Method 524.2
Dibromochloromethane	4.9	ug/L		0.5	0.08	08/15/25 19:49	08/15/25 19:49	DTS	EPA Method 524.2
Total THM	30.2	ug/L		2.0	0.3	08/15/25 19:49	08/15/25 19:49	DTS	EPA Method 524.2

Surrogate: 4-Bromofluorobenzene	76%	70-130	EPA Method 524.2
Surrogate: 1,2-Dichlorobenzene-d4	82%	70-130	EPA Method 524.2



CERTIFICATE of ANALYSIS

Microbiological/Inorganic Certification - 877

Organic Certification - 4100

Whitehouse, Village Of
Mike Hill
Po Box 2476
Whitehouse, OH 43571

Client #: 606
PO Number:
Date Received: 8/12/25 12:11
Ohio EPA Analyzed Date: 8/26/25 12:14

Sampler Name: Matt Braun
Sample Date/Time: 8/11/25 14:40
Sample Monitoring Point: DS000
Sample Type: SP
Sample Tap/Address: Hydrant 6317 Finzel Rd Whitehouse OH 43571

PWSID: OH4801612 Facility ID: DS1
Repeat Sample #:
Total Chlorine (mg/L):
Free Chlorine (mg/L):
Combined Chlorine (mg/L):

Sample ID: 375696

Lab Sample # : 5H01776-03 (Potable)

Analyte	Result	Units	Qual	Reporting Limit	MDL	Date/Time Prepared	Date/Time Analyzed	Analyst	Method
---------	--------	-------	------	-----------------	-----	--------------------	--------------------	---------	--------

Disinfection Byproducts (DBP)

Chloroform	12.6	ug/L		0.5	0.07	08/15/25 20:13	08/15/25 20:13	DTS	EPA Method 524.2
Bromoform	1.2	ug/L		0.5	0.06	08/15/25 20:13	08/15/25 20:13	DTS	EPA Method 524.2
Bromodichloromethane	6.4	ug/L		0.5	0.07	08/15/25 20:13	08/15/25 20:13	DTS	EPA Method 524.2
Dibromochloromethane	4.7	ug/L		0.5	0.08	08/15/25 20:13	08/15/25 20:13	DTS	EPA Method 524.2
Total THM	24.9	ug/L		2.0	0.3	08/15/25 20:13	08/15/25 20:13	DTS	EPA Method 524.2

Surrogate: 4-Bromofluorobenzene	75%	70-130	EPA Method 524.2
Surrogate: 1,2-Dichlorobenzene-d4	80%	70-130	EPA Method 524.2



CERTIFICATE of ANALYSIS

Microbiological/Inorganic Certification - 877

Organic Certification - 4100

Whitehouse, Village Of
Mike Hill
Po Box 2476
Whitehouse, OH 43571

Client #: 606
PO Number:
Date Received: 8/12/25 12:11
Ohio EPA Analyzed Date: 8/26/25 12:14

Sampler Name: Matt Braun
Sample Date/Time: 8/11/25 13:25
Sample Monitoring Point: DS201
Sample Type: RT
Sample Tap/Address: Hydrant 7125 Berkey Southern Rd Whitehouse OH 43571

PWSID: OH4801612 Facility ID: DS1
Repeat Sample #:
Total Chlorine (mg/L):
Free Chlorine (mg/L):
Combined Chlorine (mg/L):

Sample ID: 346403

Lab Sample # : 5H01776-04 (Potable)

Analyte	Result	Units	Qual	Reporting Limit	MDL	Date/Time Prepared	Date/Time Analyzed	Analyst	Method
---------	--------	-------	------	-----------------	-----	--------------------	--------------------	---------	--------

Disinfection Byproducts (DBP)

Monochloroacetic Acid	ND	ug/L		2.0	0.6	08/21/25 08:02	08/21/25 23:10	JRK	EPA Method 552.3
Dichloroacetic Acid	6.1	ug/L		1.0	0.5	08/21/25 08:02	08/21/25 23:10	JRK	EPA Method 552.3
Trichloroacetic Acid	ND	ug/L		1.0	0.7	08/21/25 08:02	08/21/25 23:10	JRK	EPA Method 552.3
Monobromoacetic Acid	ND	ug/L		1.0	0.5	08/21/25 08:02	08/21/25 23:10	JRK	EPA Method 552.3
Dibromoacetic Acid	1.8	ug/L		1.0	0.6	08/21/25 08:02	08/21/25 23:10	JRK	EPA Method 552.3
HAA 5 Total	7.8	ug/L		6.0	2.8	08/21/25 08:02	08/21/25 23:10	JRK	EPA Method 552.3
Surrogate: 2-Bromopropanoic Acid			112%			70-130			EPA Method 552.3
Chloroform	42.1	ug/L		0.5	0.07	08/15/25 20:36	08/15/25 20:36	DTS	EPA Method 524.2
Bromoform	1.6	ug/L		0.5	0.06	08/15/25 20:36	08/15/25 20:36	DTS	EPA Method 524.2
Bromodichloromethane	14.2	ug/L		0.5	0.07	08/15/25 20:36	08/15/25 20:36	DTS	EPA Method 524.2
Dibromochloromethane	8.0	ug/L		0.5	0.08	08/15/25 20:36	08/15/25 20:36	DTS	EPA Method 524.2
Total THM	65.9	ug/L		2.0	0.3	08/15/25 20:36	08/15/25 20:36	DTS	EPA Method 524.2
Surrogate: 4-Bromofluorobenzene			76%			70-130			EPA Method 524.2
Surrogate: 1,2-Dichlorobenzene-d4			80%			70-130			EPA Method 524.2

The contents of this report apply to the sample(s) analyzed in accordance with the chain of custody document.
No duplication of this report is allowed, except in its entirety.



CERTIFICATE of ANALYSIS

Microbiological/Inorganic Certification - 877

Organic Certification - 4100

Whitehouse, Village Of
Mike Hill
Po Box 2476
Whitehouse, OH 43571

Client #: 606
PO Number:
Date Received: 8/12/25 12:11
Ohio EPA Analyzed Date: 8/26/25 12:14

Sampler Name: Matt Braun
Sample Date/Time: 8/11/25 15:20
Sample Monitoring Point: DS000
Sample Type: SP
Sample Tap/Address: Hose Bib, 8770 Dutch Rd., Whitehouse OH 43571

PWSID: OH4801612 Facility ID: DS1
Repeat Sample #:
Total Chlorine (mg/L):
Free Chlorine (mg/L):
Combined Chlorine (mg/L):

Sample ID: 375698

Lab Sample # : 5H01776-05 (Potable)

Analyte	Result	Units	Qual	Reporting Limit	MDL	Date/Time Prepared	Date/Time Analyzed	Analyst	Method
---------	--------	-------	------	-----------------	-----	--------------------	--------------------	---------	--------

Disinfection Byproducts (DBP)

Chloroform	31.6	ug/L		0.5	0.07	08/15/25 21:01	08/15/25 21:01	DTS	EPA Method 524.2
Bromoform	1.7	ug/L		0.5	0.06	08/15/25 21:01	08/15/25 21:01	DTS	EPA Method 524.2
Bromodichloromethane	14.2	ug/L		0.5	0.07	08/15/25 21:01	08/15/25 21:01	DTS	EPA Method 524.2
Dibromochloromethane	8.1	ug/L		0.5	0.08	08/15/25 21:01	08/15/25 21:01	DTS	EPA Method 524.2
Total THM	55.6	ug/L		2.0	0.3	08/15/25 21:01	08/15/25 21:01	DTS	EPA Method 524.2

Surrogate: 4-Bromofluorobenzene	76%	70-130	EPA Method 524.2
Surrogate: 1,2-Dichlorobenzene-d4	84%	70-130	EPA Method 524.2



CERTIFICATE of ANALYSIS

Microbiological/Inorganic Certification - 877

Organic Certification - 4100

Whitehouse, Village Of
Mike Hill
Po Box 2476
Whitehouse, OH 43571

Client #: 606
PO Number:
Date Received: 8/12/25 12:11
Ohio EPA Analyzed Date: 8/26/25 12:14

Sampler Name: Matt Braun
Sample Date/Time: 8/11/25 15:00
Sample Monitoring Point: DS202
Sample Type: RT
Sample Tap/Address: Hydrant No. 426, 8911 Rd Whitehouse OH 43571

PWSID: OH4801612 Facility ID: DS1
Repeat Sample #:
Total Chlorine (mg/L):
Free Chlorine (mg/L):
Combined Chlorine (mg/L):

Sample ID: 375697

Lab Sample # : 5H01776-06 (Potable)

Analyte	Result	Units	Qual	Reporting Limit	MDL	Date/Time Prepared	Date/Time Analyzed	Analyst	Method
---------	--------	-------	------	-----------------	-----	--------------------	--------------------	---------	--------

Disinfection Byproducts (DBP)

Monochloroacetic Acid	ND	ug/L		2.0	0.6	08/21/25 08:02	08/21/25 23:34	JRK	EPA Method 552.3
Dichloroacetic Acid	5.4	ug/L		1.0	0.5	08/21/25 08:02	08/21/25 23:34	JRK	EPA Method 552.3
Trichloroacetic Acid	ND	ug/L		1.0	0.7	08/21/25 08:02	08/21/25 23:34	JRK	EPA Method 552.3
Monobromoacetic Acid	ND	ug/L		1.0	0.5	08/21/25 08:02	08/21/25 23:34	JRK	EPA Method 552.3
Dibromoacetic Acid	2.2	ug/L		1.0	0.6	08/21/25 08:02	08/21/25 23:34	JRK	EPA Method 552.3
HAA 5 Total	7.5	ug/L		6.0	2.8	08/21/25 08:02	08/21/25 23:34	JRK	EPA Method 552.3
Surrogate: 2-Bromopropanoic Acid			116%			70-130			EPA Method 552.3
Chloroform	31.5	ug/L		0.5	0.07	08/18/25 14:20	08/18/25 14:20	DTS	EPA Method 524.2
Bromoform	1.7	ug/L		0.5	0.06	08/18/25 14:20	08/18/25 14:20	DTS	EPA Method 524.2
Bromodichloromethane	13.9	ug/L		0.5	0.07	08/18/25 14:20	08/18/25 14:20	DTS	EPA Method 524.2
Dibromochloromethane	8.4	ug/L		0.5	0.08	08/18/25 14:20	08/18/25 14:20	DTS	EPA Method 524.2
Total THM	55.5	ug/L		2.0	0.3	08/18/25 14:20	08/18/25 14:20	DTS	EPA Method 524.2
Surrogate: 4-Bromofluorobenzene			80%			70-130			EPA Method 524.2
Surrogate: 1,2-Dichlorobenzene-d4			85%			70-130			EPA Method 524.2

The contents of this report apply to the sample(s) analyzed in accordance with the chain of custody document.
No duplication of this report is allowed, except in its entirety.



CERTIFICATE of ANALYSIS

Microbiological/Inorganic Certification - 877

Organic Certification - 4100

Whitehouse, Village Of
Mike Hill
Po Box 2476
Whitehouse, OH 43571

Client #: 606
PO Number:
Date Received: 8/12/25 12:11
Ohio EPA Analyzed Date: 8/26/25 12:14

Notes and Definitions

Item	Definition
J	Analyte was positively identified, the associated numerical value is estimated.
mg/kg Dry	Sample results reported on a dry weight basis
ug/L	ppb/Part per Billion
mg/L	ppm/Part per Million
ng/L	ppt/Part per Trillion
ND	Analyte NOT DETECTED at or above the method detection limit (MDL)
!	Analyte is at or above the Maximum Contaminate Level
MDL	Method Detection Limit
CFU	Colony Forming Units
MPN	Most Probable Number
NTU	Nephelometric Turbidity Unit
pCi/L	Picocuries per liter
SVI	Sludge Volume Index
%	Percent
GPD	Gallons per Day
su	Standard Units
RPD	Relative Percent Difference
%REC	Percent Recovery
Source	Sample that was matrix spiked or duplicated.

Notes:

1. Calculated analytes are based on raw data and may not reflect the rounding of the individual compounds.
2. Samples are analyzed using the information received on the request sheet and may not be analyzed when the parameters fall outside required guidelines.

**7940 Memorial Drive
Plain City, OH 43064
614-873-4654**

Ar. AR # 346405
Received: 8/12/2025
** Matrix: Potable

Request Sheet

Appear on Bottle: 346405

Information *1

Project Name: _____

Client #: 606 Client Name: Village of Whitehouse County: Lucas P.O.# _____

Sampler Name: Matt Braun SMP ID: EP001 Sample Type: ☐ Compliance (C)
☐ New Well (N)
☒ Special/Other (O)

Sample Tap: Hose bib Date Collected: 08/11/25 Time Collected: 02:15 pm
(MM/DD/YY) (hh:mm am/pm)

Tap Address: 6010 N. Texas St., Whitehouse, OH 43571

() Public Sample ☒ PWS ID #: 4801612 ☒ Facility ID #: 4855849 () Private Sample
STU ID #:

Non-Preserved Parameters	Misc. Parameters & Preservatives	SOC Parameter Groups
() 183 Asbestos	() 154 VOC (Ascorbic Acid/HCL) 524.2	() 900 GROUP 1 Method 525.2
() 158 Total (Gross) Alpha	() 213 TTHM (Ascorbic Acid/HCL) 524.2	() 899 GROUP 2 Method 515.3
() 159 Total (Gross) Beta	() 375 HAA5 (NH4CL) 552.3	() 903 GROUP 2 Method 531.1
() 254 Radium 228	() 171 Toluene 524.2 or 8260	() 898 GROUP 3 Method 508
	() 174 BTEX (Ascorbic Acid/HCL)	() 904 GROUP 3 Method 547
	() 317 Lithium	() 905 GROUP 3 Method 549.2
() 371 UV254	() 134 Titanium	() 900 GROUP 4 Method 525.2
() 354 DOC	() 157 Total Organic Halogens	() 901 GROUP 4 Method 548.1
() 1080 SUVA	() 366 Hydrogen Sulfide	() 701 Alachlor 525.2
	() 123 Sulfide	() 702 Atrazine 525.2
() 166 Bromide		() 707 Simazine 525.2
() 34 Chloride	() 1243 HAB Total Microcystins	() SOC
() 1195 Bromide Chloride Ratio		() SOC
() 746 2,3,7,8-TCDD (Dioxin)	() 1258 HAB Cyanobacteria Screening	() SOC
() 271 PAH 525.2 or 8270	Office Use Only: _____ _____ _____ _____ _____ _____	() SOC
() 124 Sulfite		() SOC
() Other		
() Other		
() Other		
() Other		
() Other		
		() 9050 MASI Use Only

N: _____ Total Containers: 2

S: _____

U: _____

Route	220	CLT
-------	-----	-----

Office/Lab	1115
------------	------

COOLER / TEMP: DQ / 12 C

Revised 9-18-23 DN

MA SI ®ENVIRONMENTAL
LABORATORIES7940 Memorial Drive
Plain City, OH 43084
614-873-4654

Cl

5H01776-02

Test Sheet

Analy

AR # 346404

Year on Bottle:

346404

** Se

Received: 8/12/2025

Matrix: Potable

Information *

Project Name: _____

Client #: 606 Client Name: Village of Whitehouse County: Lucas P.O.# _____Sampler Name: Matt Brown SMP ID: DS000 Sample Type: ☐ Compliance (C)
☐ New Well (N)
☒ Special/Other (O)Sample Tap: House bib Date Collected: 08/11/25 Time Collected: 01:50 pm
(MM/DD/YY) (hh:mm am/pm)Tap Address: 6763 Gilead St., Whitehouse, OH 43571☐ Public Sample ☒ PWS ID #: 4801612 ☒ Facility ID #: DS1 ☐ Private Sample

Non-Preserved Parameters	Misc. Parameters & Preservatives	SOC Parameter Groups
☐ 183 Asbestos	☐ 154 VOC (Ascorbic Acid/HCL) 524.2	☐ 900 GROUP 1 Method 525.2
☐ 158 Total (Gross) Alpha	☒ 213 TTHM (Ascorbic Acid/HCL) 524.2	☐ 899 GROUP 2 Method 515.3
☐ 159 Total (Gross) Beta	☐ 375 HAA5 (NH4CL) 552.3	☐ 903 GROUP 2 Method 531.1
☐ 254 Radium 228	☐ 171 Toluene 524.2 or 8260	☐ 898 GROUP 3 Method 508
	☐ 174 BTEX (Ascorbic Acid/HCL)	☐ 904 GROUP 3 Method 547
	☐ 317 Lithium	☐ 905 GROUP 3 Method 549.2
☐ 371 UV254	☐ 134 Titanium	☐ 900 GROUP 4 Method 525.2
☐ 354 DOC	☐ 157 Total Organic Halogens	☐ 901 GROUP 4 Method 548.1
☐ 1080 SUVA	☐ 366 Hydrogen Sulfide	☐ 701 Alachlor 525.2
	☐ 123 Sulfide	☐ 702 Atrazine 525.2
☐ 166 Bromide		☐ 707 Simazine 525.2
☐ 34 Chloride	☐ 1243 HAB Total Microcystins	☐ SOC
☐ 1195 Bromide Chloride Ratio		☐ SOC
☐ 746 2,3,7,8-TCDD (Dioxin)	☐ 1258 HAB Cyanobacteria Screening	☐ SOC
☐ 271 PAH 525.2 or 8270		☐ SOC
☐ 124 Sulfite		☐ SOC
☐ Other	Office Use Only: _____ _____ _____ _____ _____ _____	
☐ Other		
☐ Other		
☐ Other		
☐ Other		
		☐ 9050 MASI Use Only

N: _____ Total Containers: 1
S: _____
U: _____Route 220 CLT
Office/Lab KUF
COOLER / TEMP: 20 / 17 C

Revised 9-18-23 DN



ENVIRONMENTAL
LABORATORIES

7940 Memorial Drive
Plain City, OH 43084
614-873-4654

C

5H01776-03

Test Sheet

Anal:

AR # 375696

Appear on Bottle:

375696

** S:

Received: 8/12/2025
Matrix: Potable

Information **

Project Name: _____

Client #: 606 Client Name: Village of Whitelhouse County: Lucas P.O.# _____

Sampler Name: Max Braun SMP ID: DS000 Sample Type: ☐ Compliance (C)
☐ New Well (N)
☒ Special/Other (O)

Sample Tap: Hydrant Date Collected: 08/11/25 Time Collected: 02:40 pm
(MM/DD/YY) (hh:mm am/pm)

Tap Address: 6317 Finzel Rd., Whitelhouse, OH 43571

☐ Public Sample ☒ PWS ID #: 4801612 ☒ Facility ID #: DS1 ☐ Private Sample

Non-Preserved Parameters	Misc. Parameters & Preservatives	SOC Parameter Groups
☐ 183 Asbestos	☐ 154 VOC (Ascorbic Acid/HCL) 524.2	☐ 900 GROUP 1 Method 525.2
☐ 158 Total (Gross) Alpha	☒ 213 TTHM (Ascorbic Acid/HCL) 524.2	☐ 899 GROUP 2 Method 515.3
☐ 159 Total (Gross) Beta	☐ 375 HAA5 (NH4CL) 552.3	☐ 903 GROUP 2 Method 531.1
☐ 254 Radium 228	☐ 171 Toluene 524.2 or 8260	☐ 898 GROUP 3 Method 508
	☐ 174 BTEX (Ascorbic Acid/HCL)	☐ 904 GROUP 3 Method 547
	☐ 317 Lithium	☐ 905 GROUP 3 Method 549.2
☐ 371 UV254	☐ 134 Titanium	☐ 900 GROUP 4 Method 525.2
☐ 354 DOC	☐ 157 Total Organic Halogens	☐ 901 GROUP 4 Method 548.1
☐ 1080 SUVA	☐ 366 Hydrogen Sulfide	☐ 701 Alachlor 525.2
	☐ 123 Sulfide	☐ 702 Atrazine 525.2
☐ 166 Bromide		☐ 707 Simazine 525.2
☐ 34 Chloride	☐ 1243 HAB Total Microcystins	☐ SOC
☐ 1195 Bromide Chloride Ratio		☐ SOC
☐ 746 2,3,7,8-TCDD (Dioxin)	☐ 1258 HAB Cyanobacteria Screening	☐ SOC
☐ 271 PAH 525.2 or 8270		☐ SOC
☐ 124 Sulfite		☐ SOC
☐ Other	Office Use Only: _____ _____ _____ _____ _____ _____	
☐ Other		
☐ Other		
☐ Other		
☐ Other		
		☐ 9050 MASI Use Only

N: _____ Total Containers: 1
S: _____
U: _____

Route 220 CLF

Office/Lab CLF

COOLER / TEMP: DQ / 12 C

MA SI ®ENVIRONMENTAL
LABORATORIES7940 Memorial Drive
Plain City, OH 43064
614-873-4654

Potable Water

Ch

Analysis

** See

5H01776-04

AR # 346403

Received: 8/12/2025

Matrix: Potable

Test Sheet

Label on Bottle:

346403

Information **

Project Name: _____

Client #: 606 Client Name: Village of Whitehouse County: Lucas P.O.# _____Sampler Name: Nat Braun SMP ID: DS 201 Sample Type: ☒ Compliance (C)
☐ New Well (N)
☐ Special/Other (O)Sample Tap: Hydrant Date Collected: 08/11/25 Time Collected: 01:25 pm
(MM/DD/YY) (hh:mm am/pm)Tap Address: 7125 Berkeley Southern Rd., Whitehouse, OH 43571☐ Public Sample ☒ PWS ID #: 4801612 ☒ Facility ID #: DS1 ☐ Private Sample

Non-Preserved Parameters	Misc. Parameters & Preservatives	SOC Parameter Groups
☐ 183 Asbestos	☐ 154 VOC (Ascorbic Acid/HCL) 524.2	☐ 900 GROUP 1 Method 525.2
☐ 158 Total (Gross) Alpha	☒ 213 TTHM (Ascorbic Acid/HCL) 524.2	☐ 899 GROUP 2 Method 515.3
☐ 159 Total (Gross) Beta	☒ 375 HAA5 (NH4CL) 552.3	☐ 903 GROUP 2 Method 531.1
☐ 254 Radium 228	☐ 171 Toluene 524.2 or 8260	☐ 898 GROUP 3 Method 508
	☐ 174 BTEX (Ascorbic Acid/HCL)	☐ 904 GROUP 3 Method 547
	☐ 317 Lithium	☐ 905 GROUP 3 Method 549.2
☐ 371 UV254	☐ 134 Titanium	☐ 900 GROUP 4 Method 525.2
☐ 354 DOC	☐ 157 Total Organic Halogens	☐ 901 GROUP 4 Method 548.1
☐ 1080 SUVA	☐ 366 Hydrogen Sulfide	☐ 701 Alachlor 525.2
	☐ 123 Sulfide	☐ 702 Atrazine 525.2
☐ 166 Bromide		☐ 707 Simazine 525.2
☐ 34 Chloride	☐ 1243 HAB Total Microcystins	☐ SOC
☐ 1195 Bromide Chloride Ratio		☐ SOC
☐ 746 2,3,7,8-TCDD (Dioxin)	☐ 1258 HAB Cyanobacteria Screening	☐ SOC
☐ 271 PAH 525.2 or 8270		☐ SOC
☐ 124 Sulfite		☐ SOC
☐ Other	Office Use Only: _____ _____ _____ _____ _____ _____	
☐ Other		
☐ Other		
☐ Other		
☐ Other		
		☐ 9050 MASI Use Only

N: _____

Total Containers: 2

S: _____

U: _____

Route

220 CLE

Office/Lab

KIFCOOLER / TEMP: DQ / 12 C

Revised 9-18-23 DN



ENVIRONMENTAL
LABORATORIES

7940 Memorial Drive
Plain City, OH 43064
614-873-4654

CI

5H01776-05

Test Sheet

Analy: AR # 375698
Received: 8/12/2025
** Se Matrix: Potable

ear on Bottle: 375698
Information *:

Project Name: _____

Client #: 606 Client Name: Village of Whitehouse County: Lucas P.O.# _____

Sampler Name: Math Zauer SMP ID: D5000 Sample Type: ☐ Compliance (C)
☐ New Well (N)
☒ Special/Other (O)

Sample Tap: Hose bib Date Collected: 08/11/25 Time Collected: 03:20 pm
(MM/DD/YY) (hh:mm am/pm)

Tap Address: 8770 Dutch Rd., Whitehouse, OH 43571

☐ Public Sample ☒ PWS ID #: 4801612 ☒ Facility ID #: D51 ☐ Private Sample

Non-Preserved Parameters	Misc. Parameters & Preservatives	SOC Parameter Groups
☐ 183 Asbestos	☐ 154 VOC (Ascorbic Acid/HCL) 524.2	☐ 900 GROUP 1 Method 525.2
☐ 158 Total (Gross) Alpha	☒ 213 TTHM (Ascorbic Acid/HCL) 524.2	☐ 899 GROUP 2 Method 515.3
☐ 159 Total (Gross) Beta	☐ 375 HAA5 (NH4CL) 552.3	☐ 903 GROUP 2 Method 531.1
☐ 254 Radium 228	☐ 171 Toluene 524.2 or 8260	☐ 898 GROUP 3 Method 508
	☐ 174 BTEX (Ascorbic Acid/HCL)	☐ 904 GROUP 3 Method 547
	☐ 317 Lithium	☐ 905 GROUP 3 Method 549.2
☐ 371 UV254	☐ 134 Titanium	☐ 900 GROUP 4 Method 525.2
☐ 354 DOC	☐ 157 Total Organic Halogens	☐ 901 GROUP 4 Method 548.1
☐ 1080 SUVA	☐ 366 Hydrogen Sulfide	☐ 701 Alachlor 525.2
	☐ 123 Sulfide	☐ 702 Atrazine 525.2
☐ 166 Bromide		☐ 707 Simazine 525.2
☐ 34 Chloride	☐ 1243 HAB Total Microcystins	☐ SOC
☐ 1195 Bromide Chloride Ratio		☐ SOC
☐ 746 2,3,7,8-TCDD (Dioxin)	☐ 1258 HAB Cyanobacteria Screening	☐ SOC
☐ 271 PAH 525.2 or 8270		☐ SOC
☐ 124 Sulfite		☐ SOC
☐ Other	Office Use Only: _____ _____ _____ _____ _____ _____	
☐ Other		
☐ Other		
☐ Other		
☐ Other		
☐ Other		
		☐ 9050 MASI Use Only

N: _____ Total Containers: 1
S: _____
U: _____

Route 220 CLT
Office/Lab MAUF
COOLER / TEMP: DQ / 12 C



ENVIRONMENTAL
LABORATORIES

7940 Memorial Drive
Plain City, OH 43064
614-873-4654

5H01776-06

AR # 375697

Received: 8/12/2025

Matrix: Potable

ter
request Sheet

t Appear on Bottle:

375697

DS information *:

Project Name: _____

Client #: 606 Client Name: Village of Whitehouse County: Lucas P.O.# _____

Sampler Name: Matt Tyeum SMP ID: DS202 Sample Type: ☒ Compliance (C)
☐ New Well (N)
☐ Special/Other (O)

Sample Tap: Hydrant #426 Date Collected: 08/11/25 Time Collected: 03:00 pm
(MM/DD/YY) (hh:mm am/pm)

Tap Address: 8911 Dutch Rd., Whitehouse, OH 43571

☐ Public Sample ☒ PWS ID #: 4801612 ☒ Facility ID #: DS1 ☐ Private Sample

Non-Preserved Parameters	Misc. Parameters & Preservatives	SOC Parameter Groups
☐ 183 Asbestos	☐ 154 VOC (Ascorbic Acid/HCL) 524.2	☐ 900 GROUP 1 Method 525.2
☐ 158 Total (Gross) Alpha	☒ 213 TTHM (Ascorbic Acid/HCL) 524.2	☐ 899 GROUP 2 Method 515.3
☐ 159 Total (Gross) Beta	☒ 375 HAA5 (NH4CL) 552.3	☐ 903 GROUP 2 Method 531.1
☐ 254 Radium 228	☐ 171 Toluene 524.2 or 8260	☐ 898 GROUP 3 Method 508
	☐ 174 BTEX (Ascorbic Acid/HCL)	☐ 904 GROUP 3 Method 547
	☐ 317 Lithium	☐ 905 GROUP 3 Method 549.2
☐ 371 UV254	☐ 134 Titanium	☐ 900 GROUP 4 Method 525.2
☐ 354 DOC	☐ 157 Total Organic Halogens	☐ 901 GROUP 4 Method 548.1
☐ 1080 SUVA	☐ 366 Hydrogen Sulfide	☐ 701 Alachlor 525.2
	☐ 123 Sulfide	☐ 702 Atrazine 525.2
☐ 166 Bromide		☐ 707 Simazine 525.2
☐ 34 Chloride	☐ 1243 HAB Total Microcystins	☐ SOC
☐ 1195 Bromide Chloride Ratio		☐ SOC
☐ 746 2,3,7,8-TCDD (Dioxin)	☐ 1258 HAB Cyanobacteria Screening	☐ SOC
☐ 271 PAH 525.2 or 8270		☐ SOC
☐ 124 Sulfite		☐ SOC
☐ Other	Office Use Only: _____ _____ _____ _____ _____ _____	
☐ Other		
☐ Other		
☐ Other		
☐ Other		
		☐ 9050 MASI Use Only

N: _____ Total Containers: 2
S: _____
U: _____

Route 220 CLT
Office/Lab WLF
COOLER / TEMP: DQ / 12 C